

Fwd: ABB Transformers

From : Jason Bird <jbird@rmu.net>

Tue, Jan 02, 2018 10:20 AM

Subject : Fwd: ABB Transformers**To :** Sue messer <smesser@rochelleil.us>**Cc :** Jeff Fiegenschuh <jfiegenschuh@rochelleil.us>

----- Forwarded Message -----

From: "Randy Presnell" <randy.presnell@anixter.com>

To: "Jason Bird" <jbird@rmu.net>

Sent: Thursday, November 16, 2017 8:44:48 AM

Subject: ABB Transformers

Jason,

FYI - ABB response below.

Randy Presnell
Account Manager
Anixter, Inc
Mobile (217) 246 5493

Sent from my iPhone

Begin forwarded message:

Randy,

ABB recommends that Rochelle perform at minimum a TTR and Megger test on each transformer. Are all of these units ABB? If so, get me the serial numbers and we can look at the history and see how they were constructed and what the losses were. As I had noted earlier, these are not compliant to DOE 2006, 2010 or 2016. Even if they test ok, I would not have the confidence in them to put them in service. A one time test is different than a constant load.

Thanks,

Chris

Randy Presnell
1100 Old State Rd E
Mattoon | IL | 61938
Tel: (217) 258-0921
Mob: (217) 246-5493
randy.presnell@anixter.com
FacebookLinkedInTwitterGoogle+YouTube
