



August 4, 2017

Mr. Jason Bird
 Rochelle Municipal Utilities
 700 West Second Avenue
 Rochelle, IL 61068

Ref: Letter of Recommendation – 138KV Insulators
 B1631

Dear Mr. Bird:

Rochelle Municipal Utilities has requested quotes for the 138KV Insulators for the transmission line project along Steward Rd. Based on the long lead time of these products it is BHMGM's recommendation to have RMU purchase this material direct rather than have the contractor provide. The contractor will be providing all of the other material for this project other than the steel poles.

A total of four (4) quotes from two different vendors were received and have been reviewed for completeness and ability to meet the specification requirements. Below is a summary of the quotes:

Rochelle 138KV Insulator Quotes Summary						
Vendor	Manufacturer	Part No.	Price	Qty	Total	Lead Time
Anixter	Hubbell	S050047S2020	\$ 129.89	6	\$ 779.34	6 weeks
Anixter	Hubbell	P250047S1020	\$ 269.35	6	\$ 1,616.10	9 weeks
Anixter	Hubbell	523009-1002	\$ 490.65	96	\$ 47,102.40	5 weeks
Anixter	Hubbell	BLP308G14003	\$ 695.35	6	\$ 4,172.10	13 weeks
					\$ 53,669.94	
Anixter	NGK-Locke	301-SS410-YY-0A	\$ 121.49	6	\$ 728.94	5-6 weeks
Anixter	NGK-Locke	L2-SN331-13	\$ 422.94	6	\$ 2,537.64	5-6 weeks
Anixter	NGK-Locke	L3-SN321-13	\$ 451.75	96	\$ 43,368.00	5-6 weeks
Anixter	NGK-Locke	Braced Post	No Quote	6		
* Do not meet specification.						
UUSCO	NGK-Locke	301-SS410-YY-0A	\$ 137.00	6	\$ 822.00	5-6 weeks
UUSCO	NGK-Locke	L2-SN331-13	\$ 246.00	6	\$ 1,476.00	5-6 weeks
UUSCO	NGK-Locke	L3-SN321-13	\$ 473.00	96	\$ 45,408.00	5-6 weeks
UUSCO	NGK-Locke	Braced Post	No Quote	6		
* Do not meet specification.						
UUSCO	Maclean	S248062VX02	\$ 106.00	6	\$ 636.00	6 weeks
UUSCO	Maclean	H29020047MXSS024	\$ 230.00	6	\$ 1,380.00	10-12 weeks
UUSCO	Maclean	H391060VX15	\$ 453.00	96	\$ 43,488.00	14 weeks
UUSCO	Maclean	B2901053T12071MX	\$ 378.00	6	\$ 2,268.00	14 weeks
* Do not meet leadtime requirements.					\$ 47,772.00	

Upon review of the proposals, BHMGE recommends that the insulators order be placed with Anixter-Hubbell. Anixter – Hubbell was the only quote that was received that both meets the specification and lead time requirements. A purchase order in the amount of \$53,669.94 will need to be issued to Anixter referencing quote number U00512231.02.

Should you have any questions concerning the quotes or the project, please contact us.

BHMGE Engineers, Inc

A handwritten signature in black ink, appearing to read 'Lukas Pirok', written in a cursive style.

Lukas Pirok, P.E.