



October 7, 2020

Mr. Adam Lanning
Rochelle Municipal Utilities
700 West Second Avenue
PO Box 456
Rochelle, IL 61068

Ref: 2031K003 – Prologis Park Substation Upgrades
Equipment Purchase Recommendation

Dear Mr. Lanning:

The RMU received and opened bids on October 7, 2020 for the equipment purchase, a part of the Prologis Park Substation Upgrades project. A total of two (2) bids were received and have been reviewed for completeness and ability to meet specification requirements.

<u>Bidder</u>	<u>Total Bid Price</u>	<u>Lead Time</u>
Dis-Tran Pckgd Subs	\$578,749.00	26 weeks
Peak Sub Srvcs	\$1,259,800.00	28 weeks

The bid from Dis-Tran was the apparent low bid for Specification 2031K003, no major exceptions were listed. Dis-Tran has a good list of reference completed projects. The company appears to be in good standing and employs certified and trained craftsmen.

The low bid for the project is in accordance with the Engineer’s estimate of \$572,000 for the contract. The bid from Peak was evaluated, and it was determined their proposal was incorrectly summed, the assumed correct proposal would have been \$594,160, which is still not the low bid. Therefore, it is the recommendation of BHMGM to award the project to Dis-Tran, for the supply of the equipment.

With the City’s approval, release, and financial approval; BHMGM can assist with issuing contract documents. Should you have any questions concerning the bids or the project, please do not hesitate to contact us.

Sincerely:
BHMGM Engineers, Inc.

Jason F. Jackson, P.E.
Enclosures: Bid tab, and Dis-Tran’s Quote

10/06 Ham



2031 K003- ROCHELLE MUNICIPAL UTILITIES - PROLOGIS PARK SUBSTATION

BIDDERS / PROPOSALS	Dis-Tran <i>(Power Equipment Sales)</i>	Hamby Young	UUSCO	<i>Weak Substation Services</i>
BID SECURITY	✓			✓
Furnish the Goods & Special Services for the Equipment Purchase	<i>578749.00</i>			<i>1,259,800.00</i>
PROJECT COMPLETION TIME - PROPOSAL 1	<i>182 days</i>			<i>196</i>
	✓ Registered Bidder	✓ Registered Bidder	✓ Registered Bidder	✓ Registered Bidder
	Non-Collusion Affidavit	Non-Collusion Affidavit	Non-Collusion Affidavit	Non-Collusion Affidavit
	Bid Bond	Bid Bond	Bid Bond	Bid Bond
	Bid Form	Bid Form	Bid Form	Bid Form
	Any other documents as required by the specification	Any other documents as required by the specificaton	Any other documents as required by the specificaton	Any other documents as required by the specificaton
BHMGE ENGINEERS, INC. Consulting Engineers 630 Jeffco Blvd. Arnold, MO 63010		ROCHELLE MUNICIPAL UTILITIES Prologis Park Substation Equipment Purchase Bids Received 11:00 a.m., 10/06/20		Bid Opening Witnesses: City: <i>Mary Ham</i> BHMGE: <i>[Signature]</i>

BID FORM

TABLE OF CONTENTS

Article 1 - BID RECIPIENT	2
Article 2 - BIDDER'S ACKNOWLEDGMENTS	2
Article 3 - BIDDER'S REPRESENTATIONS	2
Article 4 - BIDDER'S CERTIFICATIONS.....	3
Article 5 - BASIS OF BID.....	4
Article 6 - TIME OF COMPLETION.....	5
Article 7 - ATTACHMENTS TO THIS BID	5
Article 8 - DEFINED TERMS.....	5
Article 9 - BID SUBMITTAL.....	6

This Bid is submitted by: DIS-TRAN Packaged Substations

BID FORM

ARTICLE 1 - BID RECIPIENT

1.01 This Bid is submitted to:

**Rochelle Municipal Utilities
420 N 6th Street
Rochelle, IL 61068**

1.02 The undersigned Bidder proposes and agrees, if this Bid is accepted, to enter into a Contract with Buyer in the form included in the Bidding Documents to furnish the Goods and Special Services as specified or indicated in the Bidding Documents, for the prices and within the times indicated in this Bid, and in accordance with the other terms and conditions of the Bidding Documents.

ARTICLE 2 - BIDDER'S ACKNOWLEDGMENTS

2.01 Bidder accepts all of the terms and conditions of the Instructions to Bidders, including without limitation those dealing with the disposition of Bid security. This Bid will remain subject to acceptance for 60 days after the Bid opening, or for such longer period of time that Bidder may agree to in writing upon request of Buyer.

ARTICLE 3 - BIDDER'S REPRESENTATIONS

3.01 In submitting this Bid, Bidder represents that:

A. Bidder has examined and carefully studied the Bidding Documents, the related data identified in the Bidding Documents, and the following Addenda, receipt of which is hereby acknowledged:

Addendum No.	Addendum Date
<u>N/A</u>	<u>N/A</u>
<u> </u>	<u> </u>
<u> </u>	<u> </u>

B. Bidder has visited the Point of Destination and site where the Goods are to be installed or Special Services will be provided and become familiar with and is satisfied as to the observable local conditions that may affect cost, progress, or the furnishing of Goods and Special Services, if required to do so by the Bidding Documents, or if, in Bidder's judgment, any local condition may affect cost, progress, or the furnishing of Goods and Special Services.

C. Bidder is familiar with and is satisfied as to all Laws and Regulations in effect as of the date of the Bid that may affect cost, progress, and the furnishing of Goods and Special Services.

- D. Bidder has carefully studied, considered, and correlated the information known to Bidder; information commonly known to sellers of similar goods doing business in the locality of the Point of Destination and the site where the Goods will be installed or where Special Services will be provided; information and observations obtained from Bidder's visits, if any, to the Point of Destination and the site where the Goods will be installed or Special Services will be provided; and any reports and drawings identified in the Bidding Documents regarding the Point of Destination and the site where the Goods will be installed or where Special Services will be provided, with respect to the effect of such information, observations, and documents on the cost, progress, and performance of Seller's obligations under the Bidding Documents.
- E. Bidder has given Engineer written notice of all conflicts, errors, ambiguities, and discrepancies that Bidder has discovered in the Bidding Documents, and the written resolution (if any) thereof by Engineer is acceptable to Bidder. -See attached bid letter for DTPS comments.
- F. The Bidding Documents are generally sufficient to indicate and convey understanding of all terms and conditions for furnishing the Goods and Special Services for which this Bid is submitted.

ARTICLE 4 - BIDDER'S CERTIFICATIONS

4.01 Bidder certifies that:

- A. This Bid is genuine and not made in the interest of or on behalf of any undisclosed individual or entity and is not submitted in conformity with any collusive agreement or rules of any group, association, organization, or corporation;
- B. Bidder has not directly or indirectly induced or solicited any other Bidder to submit a false or sham Bid;
- C. Bidder has not solicited or induced any individual or entity to refrain from bidding; and
- D. Bidder has not engaged in corrupt, fraudulent, collusive, or coercive practices in competing for the Contract. For the purposes of this Paragraph 4.01.D:
 - 1. "corrupt practice" means the offering, giving, receiving, or soliciting of anything of value likely to influence the action of a public official in the bidding process;
 - 2. "fraudulent practice" means an intentional misrepresentation of facts made (a) to influence the bidding process to the detriment of Buyer,

(b) to establish bid prices at artificial non-competitive levels, or (c) to deprive Buyer of the benefits of free and open competition;

3. "collusive practice" means a scheme or arrangement between two or more Bidders, with or without the knowledge of Buyer, a purpose of which is to establish bid prices at artificial, non-competitive levels; and
4. "coercive practice" means harming or threatening to harm, directly or indirectly, persons or their property to influence their participation in the bidding process.

ARTICLE 5 - BASIS OF BID

5.01 **Proposal No. 1** - Bidder will furnish the Goods and Special Services in accordance with the Contract Documents for the following price(s):

ITEM #	DESCRIPTION	QTY	UNIT PRICE	TOTAL PRICE
1	138kV Circuit Breaker	4	\$54,064.60	\$216,258.40
2	138kV Line Disconnect Switch	1	\$12,511.75	\$12,511.75
3	138kV Breaker Disconnect Switch	4	\$12,511.75	\$50,047.00
4	138kV CCVT	4	\$7,021.38	\$28,085.52
5	138kV Surge Arrestor	3	\$1,409.46	\$4,228.38
6	138kV Station Post Insulator	42	\$348.21	\$14,624.82
7	138kV Suspension Insulator	6	\$142.11	\$852.66
8	138kV A-Frame Deadend Support	1	\$48,521.36	\$48,521.36
9	138kV 3-Phase CCVT Support	1	\$3,899.73	\$3,899.73
10	138kV 1-Phase CCVT Support	1	\$942.54	\$942.54
11	138kV Switch Operator Platform	5	\$198.40	\$198.40
12	138kV 3-Phase Low Bus Support	7	\$4,268.11	\$29,876.77
13	138kV 3-Phase High Bus Support	7	\$5,589.19	\$39,124.33
14	138kV 3-Phase Low Vee Switch Support	4	\$5,970.27	\$23,881.08
15	65 ft Lightning Mast	7	\$12,702.70	\$88,918.90
	Lot of anchor bolts for steel structures	1	\$15,983.76	\$15,983.76

Lump Sum Total Bid Price for Proposal No. 1	\$ 578,749.00
----------------------------------------------------	----------------------

SCHEDULE GUARANTEES

Breaker Delivery:	<u>182</u>	Calendar days ARO
Disconnect Switch Delivery:	<u>182</u>	Calendar days ARO
Steel Structures Delivery:	<u>182</u>	Calendar days ARO
CCVT Delivery:	<u>182</u>	Calendar days ARO
Insulator Delivery:	<u>182</u>	Calendar days ARO

- 5.02 It is understood and agreed by the undersigned that the Municipal Utility reserves the unrestricted privilege to reject the foregoing proposal indicated above and which the Municipality may consider excessive or unreasonable; to accept such proposal which it may consider fair and reasonable.

The lump sum of the proposal shall be the basis for establishing the amount of the performance bond and for comparison of bids.

The above delivery dates and times are to be filled in by the bidder before submitting his proposal.

ARTICLE 6 - TIME OF COMPLETION

- 6.01 Bidder agrees that the work will be substantially complete on or before date specified in 5.01 and will be completed and ready for final payment in accordance with Paragraph 14.07.B of the General Conditions on or before 30 days after date specified in 5.01.
- 6.02 Bidder accepts the provisions of the Agreement as to liquidated damages.
-See attached bid letter for DTSP comments.

ARTICLE 7 - ATTACHMENTS TO THIS BID

- 7.01 The following documents are attached to and made a condition of this Bid:
- A. Bid Bond. -See attached bid letter for DTSP comments.
 - B. List of Proposed Major Suppliers.
 - C. Affidavit of Non-Collusion.
 - D. List of Project References.
 - E. Bidder's Qualifications.

ARTICLE 8 - DEFINED TERMS

- 8.01 The terms used in this Bid with initial capital letters have the meanings stated in the Instructions to Bidders and the General Conditions.

ARTICLE 9 - BID SUBMITTAL

9.01 This Bid submitted by:

If Bidder is:

An Individual

Name: N/A
By: N/A
Doing Business As: N/A
(Individual's signature)
Business address: N/A

Phone: N/A
Email address: N/A

A Partnership


Partnership Name: N/A (Seal)
By: N/A
(Signature of general partner – attach evidence of authority to sign.)
Name: (typed or printed) N/A
Business Address: N/A

Phone: N/A
Email Address: N/A

A Corporation

Corporation Name: N/A
State of Incorporation: N/A
Type: N/A
(General Business, Professional, Service, Other)
By: N/A
(Signature – attach evidence of authority to sign)
Name: *(typed or printed)* N/A
Title: N/A
(Corporate Seal)
Attest: N/A
(Signature of Corporate Secretary)
Business Address: N/A
Phone: N/A
Email Address: N/A

A Limited Liability Company (LLC)

LLC Name: DIS-TRAN Packaged Substations
State in which organized: Delaware
By: 
(Signature – attach evidence of authority to sign)
Name: *(typed or printed)* David Harrington
Business Address: 4725 Highway 28E
Pineville, LA 71360
Phone: 318-767-5527
Email: david.harrington@distran.com

A Joint Venture

First Joint Venturer
Name: N/A _____
(seal)

By: N/A _____
(Signature – attach evidence of authority to sign)

Name: *(typed or printed)* N/A _____

Title: N/A _____

Business Address: N/A _____

Phone: N/A _____

Email Address: N/A _____

Second Joint Venturer
Name: N/A _____
(seal)

By: N/A _____
(Signature – attach evidence of authority to sign)

Name: *(typed or printed)* N/A _____

Title: N/A _____

Business Address: N/A _____

Phone: N/A _____

Email Address: N/A _____

Phone and Facsimile Number, and Address for receipt of official communications to Joint Venture:

(Each joint venturer must sign. The manner of signing for each individual, partnership, corporation, and limited liability company that is a party to the joint venture should be in the manner indicated above.)

QUALIFICATIONS

PART 1 – GENERAL

1.01 SECTION INCLUDES

- A. Appointment of Counsel.
- B. Pre-qualifications.
- C. Bidder's Qualifications.
- D. Certifications.
- E. References.
- F. Signatures.

1.02 AWARD OF BID

- A. Failure of Bidder to meet all qualification criteria as stated in these Specifications shall disqualify Bidder from consideration for the Project.
- B. The Owner reserves the right to exclude Bidder from consideration due to the Bidder's failure to present with written documentation his experience and capability to complete the project to the Owner's expectations.

PART 2 – QUALIFICATIONS

2.01 APPOINTMENT OF COUNSEL – NON-RESIDENT

- A. Bidder has appointed Registered Agent Solutions, Inc., whose address is 901 S. 2nd Street Suite 201 Springfield, IL 62704, as the agent of Bidder for service of process in the event any litigation or controversy results between the Bidder and Owner arising out of the contractual relationship created by the acceptance of this Bid. Bidder agrees that the courts of the State in which the project is located will have jurisdiction over Bidder for all such purposes to the same extent as though Bidder were a resident of the State.

2.02 PRE-QUALIFICATION

- A. Failure of Bidder to meet the Pre-qualification requirements as stated in the Instruction to Bidders Bid shall disqualify Bidder from consideration for the Project.

2.03 BIDDER'S QUALIFICATIONS

- A. Bidder shall prove to the Owner's satisfaction Bidder's experience in completing similar projects, thus demonstrating the ability of the Bidder to complete the Project to the Owner's Satisfaction.
- B. Bidder shall submit written proof and abide by the written proof that the Bidder will complete a minimum of (30) thirty percent of the overall project by his own company and workers.
- C. Bidder shall submit documentation proving that the Bidder is capable of funding the Project and is not in financial hardship.
- D. Bidder shall submit documentation proving that the Bidder uses only qualified, licensed workers experienced in the line of work.
- E. Bidder's subcontractors shall be the responsibility of the Bidder and shall be considered part of the Bidder's company and shall meet qualification requirements for all aspects of the Project.

2.04 CERTIFICATIONS

- A. The Bidder certifies the following as required by law:
 - 1. Bidder has not been convicted of bribery or attempting to bribe an officer or employee of the State, nor has the Bidder made an admission of guilt of such conduct which is a matter of record, nor has an official, agent or employee of the Bidder been so convicted or made such admission of bribery on its behalf and pursuant to the direction or authorization of a responsible official thereof.
 - 2. Bidder is not barred from bidding with any unit of state or local government as a result of unlawful bid rigging.
 - 3. Under penalty of perjury, the Bidder certifies that the Federal Taxpayer Identification Number noted below is correct and the Bidder is doing business as a (please check one):
 - Individual
 - Corporation
 - Partnership
 - Corporation
 - Not-for-Profit Corporation
 - Tax Exempt Organization (IRC 501 (a) only)
 - Medical and Health Care Services Provider Corporation
 - Real Estate Agent
 - Government Entity
 - Trust or Estate

4. Bidder, if an individual, is not in default on an educational loan.

2.05 REFERENCES

- A. Bidder shall submit a minimum of three (3) written letters of recommendation with references' signatures and contact information to the Engineer.
- B. These References shall be from the Owner, Project Manager, or other individual who is knowledgeable on the project, or recent previous Projects with very similar Scope of Work completed under the current Bidder's name.
- C. Bidder shall submit a minimum of three (3) company brochures, or company information sheets, along with list of completed equivalent projects.

2.06 SIGNATURES

Firm Name: DIS-TRAN Packaged Substations

Federal Taxpayer Identification Number: 72-0728139

By: David Harrington 

Title: Proposal Department Manager

By: _____

Title: _____

Note: If the Bidder is a corporation, the legal name of the corporation shall be set forth above together with the signature of the officer or officers authorized to sign contracts on behalf of the corporation; if the Bidder is a partnership, the true name of the firm shall be set forth above together with the signature of the partner or partners authorized to sign contracts on behalf of the partnership; and if the Bidder is an individual, his signature shall be placed above. If signature is by an agent, other than an officer of a corporation or member of a partnership, a power of attorney must be submitted with the bid.

PART 3 – EXECUTION

NOT USED

END OF SECTION



4725 Highway 28 E • Pineville, LA 71360 • 318.448.0274

Rochelle Municipal Utilities

RFP PROLOGIS PARK SUBSTATION EQUIPMENT PURCHASE 2031 K003

Dis-Tran Packaged Substations 10/6/20

1. Bidder Information

1. **Firm Name:** DIS-TRAN Packaged Substations, LLC
2. **Parent Company:** Crest industries, LLC
3. **Business Address:** PO Box 5109, Alexandria, LA 71307
4. **State of Incorporation:** Delaware
5. **Number of years in business:** 55
6. **Key Personnel:**
 - a. Brittany Jackson, Proposal Coordinator, 318-427-9317, brittany.jackson@distran.com
 - b. David Harrington, Proposal Dept. Manager, 318-767-5527, david.harrington@distran.com

2. Bid Clarifications

- See the attached technical documents and DTPS material list containing detailed descriptions, ratings, options, clarifications and/or exceptions offered.
- P-200 - INSTRUCTIONS TO BIDDERS Article 8.01 - A Bid bond form was not included with RFQ documents; bond issued on AIA document A310-2010 form.
- Anticipated submittal schedule:
 - Steel Calculations for approval = 35 calendar days
 - Steel Fabrication Drawings for approval = 56 calendar days
- Anticipated Anchor Bolts Delivery = 35 calendar days ARAD (after receipt of approved designs)
- No addendum have been received for this RFQ.
- P-800 - SUPPLEMENTARY CONDITIONS Article 1.02 - Liquidated damages accepted at \$500 per day; not to exceed 5% of total contract price.
- Section 16359 Substation Structures, Part 2, Item 2.3, Section H Detail 2 - Steel will be galvanized to ASTM A123 specs regarding cleaning and galvanizing process.
- Section 16359 Substation Structures, Part 2, Item 2.3, Section H, Detail 3 - Steel will not be sandblasted prior to galvanizing.
- Steel weights based on customer provided design drawings; deviations may result in change order.





4725 Highway 28 E • Pineville, LA 71360 • 318.448.0274

3. Bidder References:

a. Basin Electric

345kV Chappelle Creek Switchyard

Chad Kuntz - Engineering Supervisor
1717 East Interstate Ave, Bismarck, ND
701-557-5743
ckuntz@bepc.com

b. El Paso Electric

13.8kV Horizon Substation

Lily Bustamante - Engineering Supervisor
3511 A. Montana BLDG O, El Paso, TX
915-543-5733
lily.bustamante@epelectric.com

c. Center Point Energy

138kV Greens Bayou Substation Hugo

Castro - Engineering Lead
1111 Louisiana Ave, Houston, TX
713-207-6131
hugo.castro@centerpointenergy.com

4. Steel Fabricator

• Klute, Inc.

1313 Road G,
York, NE 68467
Phone: 402-362-1055
www.kluteinc.com
AISC and ISO 9001:2015-certified





138kV Prologis Park Substation
Rochelle Municipal Utilities
Rochelle Municipal Utilities
Rochelle, IL

Origination Date: 10/5/2020
Proposal No: 101021SP

Item	Qty	UOM	Description	MFG	MFG Part Num	Unit Cost	Ext Cost
STRUCTURES							
S1	1	EA	138KV, A-FRAME DEADEND STRUCTURE, 40' PULL-OFF HEIGHT, 52' STATIC PULL-OFF HEIGHT, 42' BAY WIDTH *All columns are folded plate A572 GR65 and base plates A572 GR65 or Gr50 as applicable.	Klute Inc.	APPX WT = 18,250 LBS EA	\$48,521.36	\$48,521.36
S2	1	EA	138KV, 3-PHASE CCVT SUPPORT, 8'-6" STRUCTURE HEIGHT, 12' PHASE SPACING, 1 COLUMNS *All columns are folded plate A572 GR65 and base plates A572 GR65 or Gr50 as applicable.	Klute Inc.	APPX WT = 1,535 LBS EA	\$3,899.73	\$3,899.73
S3	1	EA	138KV, 1-PHASE CCVT SUPPORT, 8'-6" STRUCTURE HEIGHT *All columns are folded plate A572 GR65 and base plates A572 GR65 or Gr50 as applicable.	Klute Inc.	APPX WT = 371 LBS EA	\$942.54	\$942.54
S4	5	EA	138KV, SWITCH OPERATOR PLATFORM, 4X3	Klute Inc.	APPX WT = 145 LBS EA	\$198.40	\$992.00
S5	7	EA	138KV, THREE PHASE LOW BUS SUPPORT, 17' BUS HEIGHT, 12' PHASE SPACING, 1 COLUMNS *All columns are folded plate A572 GR65 and base plates A572 GR65 or Gr50 as applicable.	Klute Inc.	APPX WT = 1,680 LBS EA	\$4,268.11	\$29,876.77
S6	7	EA	138KV, THREE PHASE HIGH BUS SUPPORT, 25' BUS HEIGHT, 12' PHASE SPACING, 1 COLUMNS *All columns are folded plate A572 GR65 and base plates A572 GR65 or Gr50 as applicable.	Klute Inc.	APPX WT = 2,200 LBS EA	\$5,589.19	\$39,124.33
S7	4	EA	138KV, 3-PHASE LOW VEE SWITCH SUPPORT, 17' BUS HEIGHT, 12' PHASE SPACING, 2 COLUMNS *All columns are folded plate A572 GR65 and base plates A572 GR65 or Gr50 as applicable.	Klute Inc.	APPX WT = 2,350 LBS EA	\$5,970.27	\$23,881.08
S8	7	EA	65' LIGHTNING MAST *All columns are folded plate A572 GR65 and base plates A572 GR65 or Gr50 as applicable.	Klute Inc.	APPX WT = 5,000 LBS EA	\$12,702.70	\$88,918.90
MAJOR EQUIPMENT							
P4	1	EA	138KV SWITCH, GROUP OPERATED, AIR BREAK, CENTER BREAK VEE SWITCH, 650kV BIL, 2000A CONTINUOUS, TR288 GREY INSULATORS, HORIZONTAL UNDERHUNG MOUNT, MANUAL OPERATOR, MOUNTED ON DEADEND STRUCTURE	Southern States, LLC	EC-1V-5BC-138-2000	\$12,511.75	\$12,511.75
P5	4	EA	138KV SWITCH, GROUP OPERATED, AIR BREAK, CENTER BREAK VEE SWITCH, 650kV BIL, 2000A CONTINUOUS, TR288 GREY INSULATORS, HORIZONTAL UPRIGHT MOUNT, MANUAL OPERATOR, MOUNTED ON SWITCH STAND	Southern States, LLC	EC-1V-5BC-138-2000	\$12,511.75	\$50,047.00



138kV Prologis Park Substation
Rochelle Municipal Utilities
Rochelle Municipal Utilities
Rochelle, IL

Origination Date: 10/5/2020
Proposal No: 101021SP

P6	4	EA	138KV CIRCUIT BREAKER, 2000A, 40KA INTERRUPTING, 3 CYCLES, 650KV BIL, SF6 - INCLUDES GE RECOMMENDED SPARE PARTS	GE Grid Solutions, LLC	DT1-145 FK F1	\$54,064.60	\$216,258.40
P7	4	EA	CCVT, OIL-FILLED, 138KV NOMINAL, 650 BIL, SINGLE BUSHING, 80,500V PRIMARY, 1200/700:1 RATIO, TWO 115/67.08 & 115/67.08 SECONDARY WINDINGS, THERMAL RATING: 1000 VA, 0.3 W, X,Y, Z, ZZ **** Per MFG: CVT model TEMP145 offered to meet the minimum required capacitance of 6,000pF****	Trench Limited	TEMP145	\$7,021.38	\$28,085.52
P8	3	EA	SURGE ARRESTOR, STATION CLASS, POLYMER, UPRIGHT MOUNTING, WITH NEMA PAD TERMINAL, 120KV DUTY CYCLE, 88KV MCOV.	Hubbell Power Systems, Inc.	EVP008800-3001	\$1,409.46	\$4,228.38
P9	42	EA	STATION POST INSULATOR, HIGH STRENGTH 138KV, 650KV BIL, TR-289, GRAY, 2200# CANTILEVER ***QUOTED PER SPEC SECTION 16356 2.5***	Newell Porcelain	47822-7001	\$348.21	\$14,624.82
P10	6	EA	INSULATOR, SUSPENTION, 30 KIP, STANDARD LEAKAGE DISTANCE, Y CLEVIS TOP FITTING, ANSI BALL BOTTOM FITTING. ***QUOTED PER SPEC SECTION 16356 2.6***	Hubbell Power Systems, Inc.	S030047S2010	\$142.11	\$852.66
AB1	1	EA	LOT OF ANCHOR BOLTS AND TEMPLATES FOR STEEL STRUTURES	Threaded Fasteners, Inc.		\$15,983.76	\$15,983.76
						TOTAL	\$578,749.00

**UNANIMOUS WRITTEN CONSENT
OF THE SOLE MEMBER OF
DIS-TRAN PACKAGED SUBSTATIONS, LLC**

The undersigned, being the sole member (the "Member") of DIS-TRAN PACKAGED SUBSTATIONS, LLC a Delaware Limited Liability Company (the "Company"), pursuant to Section 18-404(d) of the Delaware Limited Liability Company Act, hereby adopts, by written consent, the following resolution:

RESOLVED, that, effective as of the date hereof, David Harrington is hereby authorized and empowered to execute new contracts, contract amendments, bid proposals and non-disclosure agreements, involving Company business in the name of and on behalf of the Company.

FURTHER RESOLVED, this appointment shall remain in effect until the earlier of revocation or termination of employment for any reason.

IN WITNESS WHEREOF, the Member has adopted the foregoing resolutions effective as of the 12th day of September, 2018.

Crest Operations, LLC, Sole Member of
DIS-TRAN Packaged Substations, LLC

By:



Kenneth L. Robison, CEO

NON-COLLUSION AFFIDAVIT

The Municipality reserves the right, before any award of contract is made, to require any bidder to whom it may make an award of the Principal Contract, to sign a non-collusion affidavit in the form designated below:

STATE OF Louisiana)

COUNTY OF Rapides)

David Harrington, being first duly sworn, deposes and says that he is Proposal Dept Manager * (sole owner, partner, president, secretary, etc.) of the interest of or on behalf of any undisclosed person, partnership, company, association, organization or corporation; that such bid is genuine and not collusive or sham; that said bidder has not directly or indirectly induced or solicited any other bidder to put in a false or sham bid, and has not directly or indirectly colluded, conspired, connived, or agreed with any bidder or anyone else to put in a sham bid, or that anyone shall refrain from bidding; that said bidder has not in any manner, directly or indirectly, sought by agreement, communication or conference with anyone to fix the bid price of said bidder or of any bidder to fix any overhead, profit or cost element of such bid price, or of that of any other bidder, or to secure any advantage against the public body awarding the contract or anyone interested in the proposed contract; that all statements contained in such bid are true; and, further, that said bidder has not, directly or indirectly, submitted his bid price or any breakdown thereof, or the contents thereof, or divulged information or data relative thereto, or paid and will not pay any fee in connection therewith to any corporation, partnership, company, association, organization, bid depository, or any member or agent thereof, or to any other individual except to such person or persons as have a partnership or other financial interest with said bidder in his general business.

Signed: 
Proposal Department Manager
Title

Subscribed and sworn to before me this 5 day of October, 2020.

Seal of Notary


Notary Public

* In making out this form, the title that is not applicable should be struck out. For example, if the Contractor is a corporation and this form is to be executed by its president, the words "Sole Owner", "Partner", "secretary", etc. should be struck out.

 **AIA**® Document A310™ – 2010

Bid Bond

CONTRACTOR:

(Name, legal status and address)

**DIS-TRAN Packaged Substations,
LLC
4725 Highway 28 East
Pineville, LA 71360**

SURETY:

*(Name, legal status and principal place
of business)*

**Federal Insurance Company
202B Hall's Mill Road
Whitehouse Station, NJ 08889**

OWNER:

(Name, legal status and address)

**Rochelle Municipal Utilities
420 N 6th Street
Rochelle, IL 61068**

This document has important legal consequences. Consultation with an attorney is encouraged with respect to its completion or modification.

Any singular reference to Contractor, Surety, Owner or other party shall be considered plural where applicable.

BOND AMOUNT: Five Percent (5%) of the Amount Bid-----

PROJECT:

(Name, location or address, and Project number, if any)

Prologis Park Substation Equipment Purchase, 2031 K003

The Contractor and Surety are bound to the Owner in the amount set forth above, for the payment of which the Contractor and Surety bind themselves, their heirs, executors, administrators, successors and assigns, jointly and severally, as provided herein. The conditions of this Bond are such that if the Owner accepts the bid of the Contractor within the time specified in the bid documents, or within such time period as may be agreed to by the Owner and Contractor, and the Contractor either (1) enters into a contract with the Owner in accordance with the terms of such bid, and gives such bond or bonds as may be specified in the bidding or Contract Documents, with a surety admitted in the jurisdiction of the Project and otherwise acceptable to the Owner, for the faithful performance of such Contract and for the prompt payment of labor and material furnished in the prosecution thereof; or (2) pays to the Owner the difference, not to exceed the amount of this Bond, between the amount specified in said bid and such larger amount for which the Owner may in good faith contract with another party to perform the work covered by said bid, then this obligation shall be null and void, otherwise to remain in full force and effect. The Surety hereby waives any notice of an agreement between the Owner and Contractor to extend the time in which the Owner may accept the bid. Waiver of notice by the Surety shall not apply to any extension exceeding sixty (60) days in the aggregate beyond the time for acceptance of bids specified in the bid documents, and the Owner and Contractor shall obtain the Surety's consent for an extension beyond sixty (60) days.

If this Bond is issued in connection with a subcontractor's bid to a Contractor, the term Contractor in this Bond shall be deemed to be Subcontractor and the term Owner shall be deemed to be Contractor.


When this Bond has been furnished to comply with a statutory or other legal requirement in the location of the Project, any provision in this Bond conflicting with said statutory or legal requirement shall be deemed deleted herefrom and provisions conforming to such statutory or other legal requirement shall be deemed incorporated herein. When so furnished, the intent is that this Bond shall be construed as a statutory bond and not as a common law bond.

Signed and sealed this **6th** day of **October**, **2020**



(Witness)

DIS-TRAN Packaged Substations, LLC


(Contractor as Principal) (Seal)


(Title) Commercial Director
David Ducote



(Witness)

Federal Insurance Company

(Surety) (Seal)


(Title) Mary E. Rhodes, Attorney-In-Fact

CHUBB

Power of Attorney

Federal Insurance Company | Vigilant Insurance Company | Pacific Indemnity Company

Westchester Fire Insurance Company | ACE American Insurance Company

Know All by These Presents, that **FEDERAL INSURANCE COMPANY**, an Indiana corporation, **VIGILANT INSURANCE COMPANY**, a New York corporation, **PACIFIC INDEMNITY COMPANY**, a Wisconsin corporation, **WESTCHESTER FIRE INSURANCE COMPANY** and **ACE AMERICAN INSURANCE COMPANY** corporations of the Commonwealth of Pennsylvania, do each hereby constitute and appoint Andrew P. Underwood of Mobile, Alabama; Kadie C. Crawford and Rhonda S. Crooks of Alexandria, Louisiana; Markham R. McKnight, Stephanie S. McKnight, William G. McKnight, Charles E. Reagin III, Mary E. Rhodes, Thomas M. Sandahl, Trent J. Sandahl, Tawanda A. Weatherspoon and Charlotte L. Wright of Baton Rouge, Louisiana; Jim E. Brashier, Dewey B. Mason, Patrick Mason, Kathleen Scarborough and Troy Wagener of Biloxi, Mississippi; Lisa Butler of Gulfport, Mississippi; Kimberly Barhum, David Fortenberry and Mary Jones Norval of Hattiesburg, Mississippi

each as their true and lawful Attorney-in-Fact to execute under such designation in their names and to affix their corporate seals to and deliver for and on their behalf as surety thereon or otherwise, bonds and undertakings and other writings obligatory in the nature thereof (other than bail bonds) given or executed in the course of business, and any instruments amending or altering the same, and consents to the modification or alteration of any instrument referred to in said bonds or obligations.

In Witness Whereof, said **FEDERAL INSURANCE COMPANY**, **VIGILANT INSURANCE COMPANY**, **PACIFIC INDEMNITY COMPANY**, **WESTCHESTER FIRE INSURANCE COMPANY** and **ACE AMERICAN INSURANCE COMPANY** have each executed and attested these presents and affixed their corporate seals on this 28th day of **January, 2020**.

Dawn M. Chloros

Dawn M. Chloros, Assistant Secretary

Stephen M. Haney

Stephen M. Haney, Vice President



STATE OF NEW JERSEY

County of Hunterdon

ss.

On this 28th day of **January, 2020** before me, a Notary Public of New Jersey, personally came Dawn M. Chloros and Stephen M. Haney, to me known to be Assistant Secretary and Vice President, respectively, of **FEDERAL INSURANCE COMPANY**, **VIGILANT INSURANCE COMPANY**, **PACIFIC INDEMNITY COMPANY**, **WESTCHESTER FIRE INSURANCE COMPANY** and **ACE AMERICAN INSURANCE COMPANY**, the companies which executed the foregoing Power of Attorney, and the said Dawn M. Chloros and Stephen M. Haney, being by me duly sworn, severally and each for herself and himself did depose and say that they are Assistant Secretary and Vice President, respectively, of **FEDERAL INSURANCE COMPANY**, **VIGILANT INSURANCE COMPANY**, **PACIFIC INDEMNITY COMPANY**, **WESTCHESTER FIRE INSURANCE COMPANY** and **ACE AMERICAN INSURANCE COMPANY** and know the corporate seals thereof, that the seals affixed to the foregoing Power of Attorney are such corporate seals and were thereto affixed by authority of said Companies; and that their signatures as such officers were duly affixed and subscribed by like authority.

Notarial Seal



KATHERINE J. ADELAAR
NOTARY PUBLIC OF NEW JERSEY
No. 2316885
Commission Expires July 16, 2024

Katherine J. Adelaar
Notary Public

CERTIFICATION

Resolutions adopted by the Boards of Directors of **FEDERAL INSURANCE COMPANY**, **VIGILANT INSURANCE COMPANY**, and **PACIFIC INDEMNITY COMPANY** on August 30, 2016; **WESTCHESTER FIRE INSURANCE COMPANY** on December 11, 2006; and **ACE AMERICAN INSURANCE COMPANY** on March 20, 2009:

"RESOLVED, that the following authorizations relate to the execution, for and on behalf of the Company, of bonds, undertakings, recognizances, contracts and other written commitments of the Company entered into in the ordinary course of business (each a "Written Commitment"):

- (1) Each of the Chairman, the President and the Vice Presidents of the Company is hereby authorized to execute any Written Commitment for and on behalf of the Company, under the seal of the Company or otherwise.
- (2) Each duly appointed attorney-in-fact of the Company is hereby authorized to execute any Written Commitment for and on behalf of the Company, under the seal of the Company or otherwise, to the extent that such action is authorized by the grant of powers provided for in such person's written appointment as such attorney-in-fact.
- (3) Each of the Chairman, the President and the Vice Presidents of the Company is hereby authorized, for and on behalf of the Company, to appoint in writing any person the attorney-in-fact of the Company with full power and authority to execute, for and on behalf of the Company, under the seal of the Company or otherwise, such Written Commitments of the Company as may be specified in such written appointment, which specification may be by general type or class of Written Commitments or by specification of one or more particular Written Commitments.
- (4) Each of the Chairman, the President and the Vice Presidents of the Company is hereby authorized, for and on behalf of the Company, to delegate in writing to any other officer of the Company the authority to execute, for and on behalf of the Company, under the Company's seal or otherwise, such Written Commitments of the Company as are specified in such written delegation, which specification may be by general type or class of Written Commitments or by specification of one or more particular Written Commitments.
- (5) The signature of any officer or other person executing any Written Commitment or appointment or delegation pursuant to this Resolution, and the seal of the Company, may be affixed by facsimile on such Written Commitment or written appointment or delegation.

FURTHER RESOLVED, that the foregoing Resolution shall not be deemed to be an exclusive statement of the powers and authority of officers, employees and other persons to act for and on behalf of the Company, and such Resolution shall not limit or otherwise affect the exercise of any such power or authority otherwise validly granted or vested."

I, Dawn M. Chloros, Assistant Secretary of **FEDERAL INSURANCE COMPANY**, **VIGILANT INSURANCE COMPANY**, **PACIFIC INDEMNITY COMPANY**, **WESTCHESTER FIRE INSURANCE COMPANY** and **ACE AMERICAN INSURANCE COMPANY** (the "Companies") do hereby certify that

- (i) the foregoing Resolutions adopted by the Board of Directors of the Companies are true, correct and in full force and effect,
- (ii) the foregoing Power of Attorney is true, correct and in full force and effect.

Given under my hand and seals of said Companies at Whitehouse Station, NJ, this

October 6, 2020



Dawn M. Chloros

Dawn M. Chloros, Assistant Secretary

IN THE EVENT YOU WISH TO VERIFY THE AUTHENTICITY OF THIS BOND OR NOTIFY US OF ANY OTHER MATTER, PLEASE CONTACT US AT:

Telephone (908) 903-3493 Fax (908) 903-3656 e-mail: surety@chubb.com



Item #10

Four (4) 145 kV Dead Tank Circuit Breakers according to ANSI/IEEE standards for outdoor installation with mechanical spring operating mechanisms including support structures:

▪ Type		DT1-145 FK F1
▪ Rated Nominal Voltage		138 kV
▪ Rated Maximum Voltage		145 kV
▪ Frequency		60 Hz
▪ Rated Continuous Current		2000 A
▪ Rated Short-Circuit Current		40 kA
▪ Interrupting Time		3 cycles
▪ High-Speed-Auto-Reclosure		3 Phase – Gang Operated
▪ BIL		650 kV @ 3,300' ASL
▪ Creep Distance / Material / Color		92" / Porcelain / Gray
▪ Insulating Medium		SF ₆ (Included for First Filling)
▪ Current Transformers	1-3-5 X & Y	2000:5 MR C400, TRF 2.0
	2-4-6 X & Y	2000:5 MR C400, TRF 2.0
▪ Cabinet Enclosure Rating / Material		NEMA 3R / Painted Steel
▪ Ambient Temperature		-30°C to +40°C without Tank Heaters
▪ Seismic Rating		Moderate per IEEE 693-2005
▪ Control Voltage / Range		125 VDC / (T) 70-140 VDC- (C) 90-140 VDC
▪ Motor Voltage		125 VDC
▪ Alternate Current Circuit (Lighting / Heating)		120 / 240 VAC

Features and Benefits

- The circuit breaker is qualified to M2 class for mechanical endurance in accordance with IEC 62271-100. This qualifies the circuit breaker mechanically for 10,000 Close-Open operations without maintenance.
- The circuit breaker is qualified to C2 class for capacitor switching in accordance with IEEE/ANSI C37. This qualifies the circuit breaker for switching of capacitive loads (lines, cables, shunt capacitor bank, back to back) and with very low probability of re-strike.



Spare Parts, Special Tools and Field Service

Spare Parts

Item #	Parts Description	DT1-145 FK F1 Price per Unit in USD
a	Spring Charging Motor	\$650.00
b	One (1) Trip or Close Coil	\$105.00

Prices of spare parts are valid only when ordered and delivered with the circuit breaker.

It's recommended for emergency purposes to purchase and stock a spare charging motor, trip and close coil.

Special Tools

No special tools are necessary for installation or maintenance of the breakers. We do recommend, however, having one (1) of each of the following SF₆ handling tools on site:

- Gas regulator and fill hose set One (1) included per substation
- Doble Transducer Bracket One (1) included per substation
- Hand crank for manual spring charge One (1) included per breaker

Field Service

A field service representative is not included in the base price of the circuit breakers. If service is required, pricing information is listed below.

- Initial Trip (airfare & travel time) \$3,250.00 - USD
- Ten (10) hour day (time, lodging, meals & local transportation) \$2,000.00 - USD




Comments, Clarifications and Exceptions

- * This offer is made strictly in accordance with the attached Terms and Conditions for Sale of Products and Services Form EM 104 (Grid Solutions). This document will take precedent over any terms defined in the Invitation for Bid.
- * The breakers have NEMA four (4) hole bushing terminals, made of aluminum (silver plated) and arranged in a horizontal plane
- * The circuit breaker will be provided with an external electrical trip push button with permissive control. The electrical push button is protected by the low gas lockout function and cannot be operated if the gas level should fall below safe operating levels. A mechanical trip lever is provided on each circuit breaker and located inside the mechanism enclosure.

Warranty: Sixty (60) months after installation, not to exceed sixty-six (66) months after delivery. Warranties exclude wear and tear associated with normal circuit breaker operation, circuit breakers used in special applications not covered by ANSI/IEEE C37.04, and circuit breakers that have exceeded the maximum allowable cumulated current. Warranties are based on strict accordance with the maintenance instructions found in the breaker manual. Supervision by GE personnel for installation of bushings removed for transport is mandatory to maintain the warranty and is included where applicable.

1 2 3 4

LEGEND
 A1 --- MINIMUM DISTANCE FOR BUSHING REMOVAL: 30.0" (762 mm)
 A2 --- MINIMUM DISTANCE FOR INTERRUPTER REMOVAL: 85.0" (2159 mm)
 B --- NEMA 4 HOLE TERMINAL PAD
 C --- SF6 DENSITY MONITOR
 D --- SF6 FILL VALVE
 E1 --- CHARGED/DISCHARGE INDICATORS
 E2 --- OPEN/CLOSE INDICATORS & COUNTER
 F --- CABLE ENTRANCE
 G --- RATINGS NAME PLATE (EXTERNAL)
 H --- PRESSURE RELIEF DEVICE
 J --- NEMA 2 GROUND PAD (DIAMETRICALLY OPPOSED)
 K --- LIFTING LOCATIONS
 L --- MECHANISM ACCESS
 M --- BCT NAMEPLATE (INTERNAL)
 N --- EXTERNAL GFI RECEPTACLE
 P --- EMERGENCY TRIP PUSHBUTTON



BUSHING DATA
 CREEPAGE: 92.0" (2337 mm)
 STRIKE DISTANCE: 44.5" (1130 mm)
 MATERIAL: PORCELAIN
 COLOR: ANSI 70 GRAY

CONTROL CABINET
 RATING: NEMA 3R
 MATERIAL: STEEL
 COLOR: ANSI 70 GRAY



TYPE: DT1-145FK-F1
IMPULSE WITHSTAND: 650 kV
MAXIMUM VOLTAGE: 145 kV
INTERRUPTER CURRENT RATING: 40 kA
CURRENT RATING: 1200 A

NOTES:
 1) FOUR (4) #3/4" [19 mm] ANCHOR BOLTS (ASTM A 36 OR GREATER)
 2) 3.0" [76 mm] MINIMUM PROJECTION ABOVE FOUNDATION.
 3) ANCHORING TO BE SUPPLIED BY CUSTOMER.
 4) FOUNDATION TO BE LEVEL WITHIN 0.25" [6 mm] AT FOUR (4) BASEPLATES.
 5) SHIM AND GROUT AS REQUIRED.
 6) RATED SEISMIC LEVEL 0.2g OF RRS PER IEEE 693
 7) OPERATIONAL FORCES IN ANY DIRECTION = 1112N (250 lb)
 8) HV TERMINAL STATIC HORIZONTAL FORCE (LONGITUDINAL) = 1250N (281 lb)
 9) HV TERMINAL STATIC VERTICAL FORCE (TRANSVERSE) = 750N (169 lb)
 10) HV TERMINAL STATIC VERTICAL FORCE = 1000N (225 lb)





TYPE: DT1-145FK-F1
IMPULSE WITHSTAND: 650 kV
MAXIMUM VOLTAGE: 145 kV
INTERRUPTER CURRENT RATING: 40 kA
CURRENT RATING: 1200 A

NOTES:
 1) FOUR (4) #3/4" [19 mm] ANCHOR BOLTS (ASTM A 36 OR GREATER)
 2) 3.0" [76 mm] MINIMUM PROJECTION ABOVE FOUNDATION.
 3) ANCHORING TO BE SUPPLIED BY CUSTOMER.
 4) FOUNDATION TO BE LEVEL WITHIN 0.25" [6 mm] AT FOUR (4) BASEPLATES.
 5) SHIM AND GROUT AS REQUIRED.
 6) RATED SEISMIC LEVEL 0.2g OF RRS PER IEEE 693
 7) OPERATIONAL FORCES IN ANY DIRECTION = 1112N (250 lb)
 8) HV TERMINAL STATIC HORIZONTAL FORCE (LONGITUDINAL) = 1250N (281 lb)
 9) HV TERMINAL STATIC VERTICAL FORCE (TRANSVERSE) = 750N (169 lb)
 10) HV TERMINAL STATIC VERTICAL FORCE = 1000N (225 lb)





TYPE: DT1-145FK-F1
IMPULSE WITHSTAND: 650 kV
MAXIMUM VOLTAGE: 145 kV
INTERRUPTER CURRENT RATING: 40 kA
CURRENT RATING: 1200 A

NOTES:
 1) FOUR (4) #3/4" [19 mm] ANCHOR BOLTS (ASTM A 36 OR GREATER)
 2) 3.0" [76 mm] MINIMUM PROJECTION ABOVE FOUNDATION.
 3) ANCHORING TO BE SUPPLIED BY CUSTOMER.
 4) FOUNDATION TO BE LEVEL WITHIN 0.25" [6 mm] AT FOUR (4) BASEPLATES.
 5) SHIM AND GROUT AS REQUIRED.
 6) RATED SEISMIC LEVEL 0.2g OF RRS PER IEEE 693
 7) OPERATIONAL FORCES IN ANY DIRECTION = 1112N (250 lb)
 8) HV TERMINAL STATIC HORIZONTAL FORCE (LONGITUDINAL) = 1250N (281 lb)
 9) HV TERMINAL STATIC VERTICAL FORCE (TRANSVERSE) = 750N (169 lb)
 10) HV TERMINAL STATIC VERTICAL FORCE = 1000N (225 lb)





TYPE: DT1-145FK-F1
IMPULSE WITHSTAND: 650 kV
MAXIMUM VOLTAGE: 145 kV
INTERRUPTER CURRENT RATING: 40 kA
CURRENT RATING: 1200 A

NOTES:
 1) FOUR (4) #3/4" [19 mm] ANCHOR BOLTS (ASTM A 36 OR GREATER)
 2) 3.0" [76 mm] MINIMUM PROJECTION ABOVE FOUNDATION.
 3) ANCHORING TO BE SUPPLIED BY CUSTOMER.
 4) FOUNDATION TO BE LEVEL WITHIN 0.25" [6 mm] AT FOUR (4) BASEPLATES.
 5) SHIM AND GROUT AS REQUIRED.
 6) RATED SEISMIC LEVEL 0.2g OF RRS PER IEEE 693
 7) OPERATIONAL FORCES IN ANY DIRECTION = 1112N (250 lb)
 8) HV TERMINAL STATIC HORIZONTAL FORCE (LONGITUDINAL) = 1250N (281 lb)
 9) HV TERMINAL STATIC VERTICAL FORCE (TRANSVERSE) = 750N (169 lb)
 10) HV TERMINAL STATIC VERTICAL FORCE = 1000N (225 lb)





TYPE: DT1-145FK-F1
IMPULSE WITHSTAND: 650 kV
MAXIMUM VOLTAGE: 145 kV
INTERRUPTER CURRENT RATING: 40 kA
CURRENT RATING: 1200 A

NOTES:
 1) FOUR (4) #3/4" [19 mm] ANCHOR BOLTS (ASTM A 36 OR GREATER)
 2) 3.0" [76 mm] MINIMUM PROJECTION ABOVE FOUNDATION.
 3) ANCHORING TO BE SUPPLIED BY CUSTOMER.
 4) FOUNDATION TO BE LEVEL WITHIN 0.25" [6 mm] AT FOUR (4) BASEPLATES.
 5) SHIM AND GROUT AS REQUIRED.
 6) RATED SEISMIC LEVEL 0.2g OF RRS PER IEEE 693
 7) OPERATIONAL FORCES IN ANY DIRECTION = 1112N (250 lb)
 8) HV TERMINAL STATIC HORIZONTAL FORCE (LONGITUDINAL) = 1250N (281 lb)
 9) HV TERMINAL STATIC VERTICAL FORCE (TRANSVERSE) = 750N (169 lb)
 10) HV TERMINAL STATIC VERTICAL FORCE = 1000N (225 lb)



TYPE: DT1-145FK-F1
IMPULSE WITHSTAND: 650 kV
MAXIMUM VOLTAGE: 145 kV
INTERRUPTER CURRENT RATING: 40 kA
CURRENT RATING: 1200 A

NOTES:
 1) FOUR (4) #3/4" [19 mm] ANCHOR BOLTS (ASTM A 36 OR GREATER)
 2) 3.0" [76 mm] MINIMUM PROJECTION ABOVE FOUNDATION.
 3) ANCHORING TO BE SUPPLIED BY CUSTOMER.
 4) FOUNDATION TO BE LEVEL WITHIN 0.25" [6 mm] AT FOUR (4) BASEPLATES.
 5) SHIM AND GROUT AS REQUIRED.
 6) RATED SEISMIC LEVEL 0.2g OF RRS PER IEEE 693
 7) OPERATIONAL FORCES IN ANY DIRECTION = 1112N (250 lb)
 8) HV TERMINAL STATIC HORIZONTAL FORCE (LONGITUDINAL) = 1250N (281 lb)
 9) HV TERMINAL STATIC VERTICAL FORCE (TRANSVERSE) = 750N (169 lb)
 10) HV TERMINAL STATIC VERTICAL FORCE = 1000N (225 lb)



OUTLINE DRAWING DT1-145FK F1 **SHT 1 OF 1**

Grid Solutions
 One Power Lane
 Charleroi, PA 15022



DRAWING No.: DT1-145FK F1

MATERIAL ID: CC

ORDER No.: X

SHT 1 OF 1

D

A

B

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

C

D

1

2

3

4

TERMINAL BLOCK WIRING

TB11	
121	EAT-50
122	EAT-54
123	
124	
125	
126	011-53
127	011-42
128	011-41
129	
130	
131	
132	
133	
134	

TB1	
811	
812	
813	
814	
815	
816	
817	
818	
819	
820	
821	
822	
823	
824	
825	
826	
827	
828	
829	
830	
831	
832	
833	
834	
835	
836	
837	
838	
839	
840	
841	
842	
843	
844	
845	
846	
847	
848	
849	
850	
851	
852	
853	
854	
855	
856	
857	
858	
859	
860	
861	
862	
863	
864	
865	
866	
867	
868	
869	
870	
871	
872	
873	
874	
875	
876	
877	
878	
879	
880	
881	
882	
883	
884	
885	
886	
887	
888	
889	
890	
891	
892	
893	
894	
895	
896	
897	
898	
899	
900	


TB2	
102	102-7
103	102-8
104	102-9
105	102-10
106	102-11
107	102-12
108	102-13
109	102-14
110	102-15
111	102-16
112	102-17
113	102-18
114	102-19
115	102-20
116	102-21
117	102-22
118	102-23
119	102-24
120	102-25
121	102-26
122	102-27
123	102-28
124	102-29
125	102-30
126	102-31
127	102-32
128	102-33
129	102-34
130	102-35
131	102-36
132	102-37
133	102-38
134	102-39
135	102-40
136	102-41
137	102-42
138	102-43
139	102-44
140	102-45
141	102-46
142	102-47
143	102-48
144	102-49
145	102-50
146	102-51
147	102-52
148	102-53
149	102-54
150	102-55
151	102-56
152	102-57
153	102-58
154	102-59
155	102-60
156	102-61
157	102-62
158	102-63
159	102-64
160	102-65
161	102-66
162	102-67
163	102-68
164	102-69
165	102-70
166	102-71
167	102-72
168	102-73
169	102-74
170	102-75
171	102-76
172	102-77
173	102-78
174	102-79
175	102-80
176	102-81
177	102-82
178	102-83
179	102-84
180	102-85
181	102-86
182	102-87
183	102-88
184	102-89
185	102-90
186	102-91
187	102-92
188	102-93
189	102-94
190	102-95
191	102-96
192	102-97
193	102-98
194	102-99
195	102-100
196	102-101
197	102-102
198	102-103
199	102-104
200	102-105
201	102-106
202	102-107
203	102-108
204	102-109
205	102-110
206	102-111
207	102-112
208	102-113
209	102-114
210	102-115
211	102-116
212	102-117
213	102-118
214	102-119
215	102-120
216	102-121
217	102-122
218	102-123
219	102-124
220	102-125
221	102-126
222	102-127
223	102-128
224	102-129
225	102-130
226	102-131
227	102-132
228	102-133
229	102-134
230	102-135
231	102-136
232	102-137
233	102-138
234	102-139
235	102-140
236	102-141
237	102-142
238	102-143
239	102-144
240	102-145
241	102-146
242	102-147
243	102-148
244	102-149
245	102-150
246	102-151
247	102-152
248	102-153
249	102-154
250	102-155
251	102-156
252	102-157
253	102-158
254	102-159
255	102-160
256	102-161
257	102-162
258	102-163
259	102-164
260	102-165
261	102-166
262	102-167
263	102-168
264	102-169
265	102-170
266	102-171
267	102-172
268	102-173
269	102-174
270	102-175
271	102-176
272	102-177
273	102-178
274	102-179
275	102-180
276	102-181
277	102-182
278	102-183
279	102-184
280	102-185
281	102-186
282	102-187
283	102-188
284	102-189
285	102-190
286	102-191
287	102-192
288	102-193
289	102-194
290	102-195
291	102-196
292	102-197
293	102-198
294	102-199
295	102-200
296	102-201
297	102-202
298	102-203
299	102-204
300	102-205
301	102-206
302	102-207
303	102-208
304	102-209
305	102-210
306	102-211
307	102-212
308	102-213
309	102-214
310	102-215
311	102-216
312	102-217
313	102-218
314	102-219
315	102-220
316	102-221
317	102-222
318	102-223
319	102-224
320	102-225
321	102-226
322	102-227
323	102-228
324	102-229
325	102-230
326	102-231
327	102-232
328	102-233
329	102-234
330	102-235
331	102-236
332	102-237
333	102-238
334	102-239
335	102-240
336	102-241
337	102-242
338	102-243
339	102-244
340	102-245
341	102-246
342	102-247
343	102-248
344	102-249
345	102-250
346	102-251
347	102-252
348	102-253
349	102-254
350	102-255
351	102-256
352	102-257
353	102-258
354	102-259
355	102-260
356	102-261
357	102-262
358	102-263
359	102-264
360	102-265
361	102-266
362	102-267
363	102-268
364	102-269
365	102-270
366	102-271
367	102-272
368	102-273
369	102-274
370	102-275
371	102-276
372	102-277
373	102-278
374	102-279
375	102-280
376	102-281
377	102-282
378	102-283
379	102-284
380	102-285
381	102-286
382	102-287
383	102-288
384	102-289
385	102-290
386	102-291
387	102-292
388	102-293
389	102-294
390	102-295
391	102-296
392	102-297
393	102-298
394	102-299
395	102-300
396	102-301
397	102-302
398	102-303
399	102-304
400	102-305
401	102-306
402	102-307
403	102-308
404	102-309
405	102-310
406	102-311
407	102-312
408	102-313
409	102-314
410	102-315
411	102-316
412	102-317
413	102-318
414	102-319
415	102-320
416	102-321
417	102-322
418	102-323
419	102-324
420	102-325
421	102-326
422	102-327
423	102-328
424	102-329
425	102-330
426	102-331
427	102-332
428	102-333
429	102-334
430	102-335
431	102-336
432	102-337
433	102-338
434	102-339
435	102-340
436	102-341
437	102-342
438	102-343
439	102-344
440	102-345
441	102-346
442	102-347
443	102-348
444	102-349
445	102-350
446	102-351
447	102-352
448	102-353
449	102-354
450	102-355
451	102-356
452	102-357
453	102-358
454	102-359
455	102-360
456	102-361
457	102-362
458	102-363
459	102-364
460	102-365
461	102-366
462	102-367
463	102-368
464	102-369
465	102-370
466	102-371
467	102-372
468	102-373
469	102-374
470	102-375
471	102-376
472	102-377
473	102-378
474	102-379
475	102-380
476	102-381
477	102-382
478	102-383
479	102-384
480	102-385
481	102-386
482	102-387
483	102-388
484	102-389
485	102-390
486	102-391
487	102-392
488	102-393
489	102-394
490	102-395
491	102-396
492	102-397
493	102-398
494	102-399
495	102-400
496	102-401
497	102-402
498	102-403
499	102-404
500	102-405
501	102-406
502	102-407
503	102-408
504	102-409
505	102-410
506	102-411
507	102-412
508	102-413
509	102-414
510	102-415
511	102-416
512	102-417
513	102-418
514	102-419
515	102-420
516	102-421
517	102-422
518	102-423

ITEM	QTY	SAP #	MFR #	MFR	DESCRIPTION	DEVICE ID
001	001	CC410504-017	E025812	GENERAL ELECTRIC	TERMINAL BLOCK 12PT	TB11
002	001	CC410504-017	E025812	GENERAL ELECTRIC	TERMINAL BLOCK 12PT	TB1, TB2, TB3
003	001	CC410504-019	E025806	GENERAL ELECTRIC	TERMINAL BLOCK 6PT	TB4
004	012	CC410504-003	E027806S	GENERAL ELECTRIC	TERMINAL BLOCK 6PT, SHORTING	3X, 3Y, 4X, 4Y, 5X, 5Y, 6X, 6Y, 1X, 1Y, 2X, 2Y
005	001	CC410832-019	1-410-032-P19	GRID SOLUTIONS	CABINET LIGHT	L1
006	001	CC411723-001	E09-30A	CHERRY	DOOR SWITCH, 10A, 125/250VAC	LS1
007	001	CC410634-000	1SA091	ELECTROMODE	ADJUSTABLE THERMOSTAT 45-90F (7-32C)	TH1
008	001	CC410635-000	201-J	STATES	KNIFE SWITCH 1 POLE	S8
009	004	CC410635-009	202-AW	STATES	KNIFE SWITCH 2 POLE	S3, S4, S1, S2
010	001	CC410640-001	1P1016	PIEPITT	RECEPTACLE ENCLOSURE	TH1
011	001	CC410640-009	1P1016	PIEPITT	RECEPTACLE ENCLOSURE	PL1
012	001	CC410640-003	GFVSLR OR =	HUBBELL	120VAC 15A NEMA TYPE S-1SR (6FC) DUPLEX RECEPTACLE	PL1
013	001	CC410640-001	GFVFC-1BCV	HUBBELL	RECEPTACLE WEATHERPROOF COVER	PL1
014	002	CC410641-073	CLJPF13E5	PHOENIX	END CLAMP	END10, END03
015	007	CC410650-006	1-410-050-P6	GRID SOLUTIONS	FUSE 15A CLASS RK5	S3, S3, S8, S1, S1, S2, S2
016	002	CC410650-007	1-410-050-P7	GRID SOLUTIONS	FUSE 20A CLASS RK5	S4, S4
017	001	CC410748-201	CS8C-222-1100	SPRECHER + SCHUH	CONTROL RELAY 4NO 4NC (125 VDC)	EA1
018	001	CC410749-201	CS8C-222-1100	SPRECHER + SCHUH	CONTROL RELAY 2NO 2NC (125 VDC)	EA1
019	001	CC410749-206	CS8-P22	SPRECHER + SCHUH	AUXILIARY CONTACT	EA1
020	001	CC413888-004	CIR408NXX 120VAC	CHROMALOX	ANTICONDENSATION HEATER ASSY 120VAC	H1
021	009	CC410601	1-416-091	GRID SOLUTIONS	COPPER STRAP	S2, S2, S3, S3, S4, S4, S6, S1, S1
022	001	CC416206-004	1-416-206-P4	GRID SOLUTIONS	TERMINAL BLOCK COVER AUX 6PT	B
023	001	CC416668-001	1-416-668-P1	GRID SOLUTIONS	PUSH BUTTON / IND LITE BRACKET	LS1
024	001	CC417056-P1	1-417-056-P1	GRID SOLUTIONS	SWITCH BRACKET	L1
025	001	CC417125-001	GEL-40A15/20V 15189	GENERAL ELECTRIC	LIGHT BULB 40W 120VAC	L1
026	001	CC417294-001	1-417-294-G1	WKA	SPRING CHARGE MOTOR FOR FK3-1/131	M1
027	001	CC990024-001	2-990-024-P1	GRID SOLUTIONS	DENSITY MONITOR (93.78,74) PSIG-BAR SCALE - PURE SF6	EGA
028	001	CC990035-001	2-990-035-P1	GRID SOLUTIONS	MECHANISM PANEL	PAN11
029	001	CC990158-003	2-990-158-P3	GRID SOLUTIONS	DT12.3 RELAY PANEL, VERSION 3	PAN17
030	004	CC991268-001	2-991-268-P1	GRID SOLUTIONS	6PT 1/8 MOUNTING STRIP-NEW	PAN12, PAN13, PAN14, PAN15
031	001	CC410748-001	1E008	BUSSELMANN	AUX. TERMINAL BLOCK 6 PT	HT1
032	001	CC410748-001	1E008	BUSSELMANN	AUX. TERMINAL BLOCK 6 PT	HT1
033	003	CC413188-023	WKO SER B	C3CONTROLS	PUSH BUTTON, NO CONTACT, SER B	PB1, PB2, PB3
034	002	CC413188-025	W22P65-FR SER B	C3CONTROLS	PUSH BUTTON, BK X 1NO	PB2, PB3
035	001	CC413188-026	W22P65-FR SER B	C3CONTROLS	PUSH BUTTON, RED, 1NO	PB2, PB3
036	001	CC966188-002	KTA7-25C-16A	SPRECHER+SCHUH	MOTOR CIRCUIT CONTROLLER 10-16A	DT1
037	001	CC966188-004	KT7-PA1-11	SPRECHER+SCHUH	AUX CONTACT FOR MOTOR CONTROLLER	DT1
038	001	CC410651-003	RF3A1SPT	MARATHON	FUSED KNIFE SWITCH 1 POLE 15A	S6
039	003	CC410651-002	RF3A2SPT	MARATHON	FUSED KNIFE SWITCH 2 POLE 15A	S2, S3, S1
040	001	CC410651-002	RF3A2SPT	MARATHON	FUSED KNIFE SWITCH 2 POLE 20A	S4
041	001	CC410651-002	GROUND_BAR	MARATHON	GROUND BAR, 24PT	GND1
042	003	CC410504-017	E025812	GENERAL ELECTRIC	TERMINAL BLOCK 12PT	TB5, TB6, TB7
043	003	CC410504-017	E025812	GENERAL ELECTRIC	TERMINAL BLOCK 12PT	TB10, TB8, TB9
044	003	CC49-102-110-20	49-102-110-20	GENERAL ELECTRIC	COIL (125 VDC)	MC, MD, WE
045	005	CC49-105-100-01	49-105-100-01	GENERAL ELECTRIC	AUXILIARY SWITCH FK3-X	MA1, MA2, MA3, MA4, MB1
046	001	CC417025-002	1-417-925-G2	GRID SOLUTIONS	STANDARD CIRCUIT CONNECTOR	SCC

SAMPLE DRAWING

MATERIAL ID: CCOT1-145FK-F1-001
ORDER No.

CUSTOMER ORDER No.
SUBSTATION: SERIAL No.

CUSTOMER EQ. No. 

DRAWING No.: DT1-145FK F1

Grid Solutions
One Power Lane
Chatham, PA 15022

SHT 9 OF 13

REV DESCRIPTION


ECN NO.

DRAWN BY DATE CHECKED DATE

DRAWN CHECKED DATE

BILL OF MATERIALS

A B C D





1X

1X-21	2X1
1X-22	2X2
1X-23	2X3
1X-24	2X4
1X-25	2X5
1X-26	2X6
1X-27	2X7
1X-28	2X8
1X-29	2X9
1X-30	2X10
1X-31	2X11
1X-32	2X12
1X-33	2X13
1X-34	2X14
1X-35	2X15
1X-36	2X16
1X-37	2X17
1X-38	2X18
1X-39	2X19
1X-40	2X20
1X-41	2X21
1X-42	2X22
1X-43	2X23
1X-44	2X24
1X-45	2X25
1X-46	2X26
1X-47	2X27
1X-48	2X28
1X-49	2X29
1X-50	2X30
1X-51	2X31
1X-52	2X32
1X-53	2X33
1X-54	2X34
1X-55	2X35
1X-56	2X36
1X-57	2X37
1X-58	2X38
1X-59	2X39
1X-60	2X40
1X-61	2X41
1X-62	2X42
1X-63	2X43
1X-64	2X44
1X-65	2X45
1X-66	2X46
1X-67	2X47
1X-68	2X48
1X-69	2X49
1X-70	2X50
1X-71	2X51
1X-72	2X52
1X-73	2X53
1X-74	2X54
1X-75	2X55
1X-76	2X56
1X-77	2X57
1X-78	2X58
1X-79	2X59
1X-80	2X60
1X-81	2X61
1X-82	2X62
1X-83	2X63
1X-84	2X64
1X-85	2X65
1X-86	2X66
1X-87	2X67
1X-88	2X68
1X-89	2X69
1X-90	2X70
1X-91	2X71
1X-92	2X72
1X-93	2X73
1X-94	2X74
1X-95	2X75
1X-96	2X76
1X-97	2X77
1X-98	2X78
1X-99	2X79
1X-100	2X80
1X-101	2X81
1X-102	2X82
1X-103	2X83
1X-104	2X84
1X-105	2X85
1X-106	2X86
1X-107	2X87
1X-108	2X88
1X-109	2X89
1X-110	2X90
1X-111	2X91
1X-112	2X92
1X-113	2X93
1X-114	2X94
1X-115	2X95
1X-116	2X96
1X-117	2X97
1X-118	2X98
1X-119	2X99
1X-120	2X100
1X-121	2X101
1X-122	2X102
1X-123	2X103
1X-124	2X104
1X-125	2X105
1X-126	2X106
1X-127	2X107
1X-128	2X108
1X-129	2X109
1X-130	2X110
1X-131	2X111
1X-132	2X112
1X-133	2X113
1X-134	2X114
1X-135	2X115
1X-136	2X116
1X-137	2X117
1X-138	2X118
1X-139	2X119
1X-140	2X120
1X-141	2X121
1X-142	2X122
1X-143	2X123
1X-144	2X124
1X-145	2X125
1X-146	2X126
1X-147	2X127
1X-148	2X128
1X-149	2X129
1X-150	2X130
1X-151	2X131
1X-152	2X132
1X-153	2X133
1X-154	2X134
1X-155	2X135
1X-156	2X136
1X-157	2X137
1X-158	2X138
1X-159	2X139
1X-160	2X140
1X-161	2X141
1X-162	2X142
1X-163	2X143
1X-164	2X144
1X-165	2X145
1X-166	2X146
1X-167	2X147
1X-168	2X148
1X-169	2X149
1X-170	2X150
1X-171	2X151
1X-172	2X152
1X-173	2X153
1X-174	2X154
1X-175	2X155
1X-176	2X156
1X-177	2X157
1X-178	2X158
1X-179	2X159
1X-180	2X160
1X-181	2X161
1X-182	2X162
1X-183	2X163
1X-184	2X164
1X-185	2X165
1X-186	2X166
1X-187	2X167
1X-188	2X168
1X-189	2X169
1X-190	2X170
1X-191	2X171
1X-192	2X172
1X-193	2X173
1X-194	2X174
1X-195	2X175
1X-196	2X176
1X-197	2X177
1X-198	2X178
1X-199	2X179
1X-200	2X180
1X-201	2X181
1X-202	2X182
1X-203	2X183
1X-204	2X184
1X-205	2X185
1X-206	2X186
1X-207	2X187
1X-208	2X188
1X-209	2X189
1X-210	2X190
1X-211	2X191
1X-212	2X192
1X-213	2X193
1X-214	2X194
1X-215	2X195
1X-216	2X196
1X-217	2X197
1X-218	2X198
1X-219	2X199
1X-220	2X200
1X-221	2X201
1X-222	2X202
1X-223	2X203
1X-224	2X204
1X-225	2X205
1X-226	2X206
1X-227	2X207
1X-228	2X208
1X-229	2X209
1X-230	2X210
1X-231	2X211
1X-232	2X212
1X-233	2X213
1X-234	2X214
1X-235	2X215
1X-236	2X216
1X-237	2X217
1X-238	2X218
1X-239	2X219
1X-240	2X220
1X-241	2X221
1X-242	2X222
1X-243	2X223
1X-244	2X224
1X-245	2X225
1X-246	2X226
1X-247	2X227
1X-248	2X228
1X-249	2X229
1X-250	2X230
1X-251	2X231
1X-252	2X232
1X-253	2X233
1X-254	2X234
1X-255	2X235
1X-256	2X236
1X-257	2X237
1X-258	2X238
1X-259	2X239
1X-260	2X240
1X-261	2X241
1X-262	2X242
1X-263	2X243
1X-264	2X244
1X-265	2X245
1X-266	2X246
1X-267	2X247
1X-268	2X248
1X-269	2X249
1X-270	2X250
1X-271	2X251
1X-272	2X252
1X-273	2X253
1X-274	2X254
1X-275	2X255
1X-276	2X256
1X-277	2X257
1X-278	2X258
1X-279	2X259
1X-280	2X260
1X-281	2X261
1X-282	2X262
1X-283	2X263
1X-284	2X264
1X-285	2X265
1X-286	2X266
1X-287	2X267
1X-288	2X268
1X-289	2X269
1X-290	2X270
1X-291	2X271
1X-292	2X272
1X-293	2X273
1X-294	2X274
1X-295	2X275
1X-296	2X276
1X-297	2X277
1X-298	2X278
1X-299	2X279
1X-300	2X280
1X-301	2X281
1X-302	2X282
1X-303	2X283
1X-304	2X284
1X-305	2X285
1X-306	2X286
1X-307	2X287
1X-308	2X288
1X-309	2X289
1X-310	2X290
1X-311	2X291
1X-312	2X292
1X-313	2X293
1X-314	2X294
1X-315	2X295
1X-316	2X296
1X-317	2X297
1X-318	2X298
1X-319	2X299
1X-320	2X300
1X-321	2X301
1X-322	2X302
1X-323	2X303
1X-324	2X304
1X-325	2X305
1X-326	2X306
1X-327	2X307
1X-328	2X308
1X-329	2X309
1X-330	2X310
1X-331	2X311
1X-332	2X312
1X-333	2X313
1X-334	2X314
1X-335	2X315
1X-336	2X316
1X-337	2X317
1X-338	2X318
1X-339	2X319
1X-340	2X320
1X-341	2X321
1X-342	2X322
1X-343	2X323
1X-344	2X324
1X-345	2X325
1X-346	2X326
1X-347	2X327
1X-348	2X328
1X-349	2X329
1X-350	2X330
1X-351	2X331
1X-352	2X332
1X-353	2X333
1X-354	2X334
1X-355	2X335
1X-356	2X336
1X-357	2X337
1X-358	2X338
1X-359	2X339
1X-360	2X340
1X-361	2X341
1X-362	2X342
1X-363	2X343
1X-364	2X344
1X-365	2X345
1X-366	2X346
1X-367	2X347
1X-368	2X348
1X-369	2X349
1X-370	2X350
1X-371	2X351
1X-372	2X352
1X-373	2X353
1X-374	2X354
1X-375	2X355
1X-376	2X356
1X-377	2X357
1X-378	2X358
1X-379	2X359
1X-380	2X360
1X-381	2X361
1X-382	2X362
1X-383	2X363
1X-384	2X364
1X-385	2X365
1X-386	2X366
1X-387	2X367
1X-388	2X368
1X-389	2X369
1X-390	2X370
1X-391	2X371
1X-392	2X372
1X-393	2X373
1X-394	2X374
1X-395	2X375
1X-396	2X376
1X-397	2X377
1X-398	2X378
1X-399	2X379
1X-400	2X380
1X-401	2X381
1X-402	2X382
1X-403	2X383
1X-404	2X384
1X-405	2X385
1X-406	2X386
1X-407	2X387
1X-408	2X388
1X-409	2X389
1X-410	2X390
1X-411	2X391
1X-412	2X392
1X-413	2X393
1X-414	2X394
1X-415	2X395
1X-416	2X396
1X-417	2X397
1X-418	2X398
1X-419	2X399
1X-420	2X400
1X-421	2X401
1X-422	2X402
1X-423	2X403
1X-424	2X404
1X-425	2X405
1X-426	2X406
1X-427	2X407
1X-428	2X408
1X-429	2X409
1X-430	2X410
1X-431	2X411
1X-432	2X412
1X-433	2X413
1X-434	2X414
1X-435	2X415
1X-436	2X416
1X-437	2X417
1X-438	2X418
1X-439	2X419
1X-440	2X420
1X-441	2X421
1X-442	2X422
1X-443	2X423
1X-444	2X424
1X-445	2X425
1X-446	2X426
1X-447	2X427
1X-448	2X428
1X-449	2X429
1X-450	2X430
1X-451	2X431
1X-452	2X432
1X-453	2X433
1X-454	2X434
1X-455	2X435
1X-456	2X436
1X-457	2X437
1X-458	2X438
1X-459	2X439
1X-460	2X440
1X-461	2X441
1X-462	2X442
1X-463	2X443
1X-464	2X444
1X-465	2X445
1X-466	2X446
1X-467	2X447
1X-468	2X448
1X-469	2X449
1X-470	2X450
1X-471	2X451
1X-472	2X452
1X-473	2X453
1X-474	2X454
1X-475	2X455
1X-476	2X456
1X-477	2X457
1X-478	2X458
1X-479	2X459
1X-480	2X460
1X-481	2X461
1X-482	2X462
1X-483	2X463
1X-484	2X464
1X-485	2X465
1X-486	2X466
1X-487	2X467
1X-488	2X468
1X-489	2X469
1X-490	2X470
1X-491	2X471
1X-492	2X472
1X-493	2X473
1X-494	2X474
1X-495	2X475

A B C D

RATINGS NAMEPLATE



NOTES
 1) ALL TUBING IS 3/8" STAINLESS.
 2) GAS SAMPLING CAN BE DONE THROUGH FILL VALVE.
 3) PRESSURE REGULATOR IS TO BE LOCATED 100 mm FROM GAS PRING.
 4) PRESSURE SWITCHES ARE LOCATED INSIDE THE DENSITY GAUGE HOUSING

REV	DESCRIPTION	ECN NO.	DRAWN BY	CHECKED	DATE

CUSTOMER ORDER No.	CCDT1-145FK-F1-001
SUBSTATION SERIAL No.	
CUSTOMER EQ. No.	

Grid Solutions One Power Lane Chalfont, PA 19322	DRAWING No. DT1-145FK F1
--------------------------------------------------------	--------------------------

SHT 11 OF 13	MATERIAL ID: CCDT1-145FK-F1-001
	ORDER No.

</	

BCT TERMINAL BLOCK MARKER STRIPS

1X	2X	3X	4X	5X	6X	1X	2X	3X	4X	5X	6X	1X	2X	3X	4X	5X	6X
1X1	2X1	3X1	4X1	5X1	6X1	1X2	2X2	3X2	4X2	5X2	6X2	1X3	2X3	3X3	4X3	5X3	6X3
1X4	2X4	3X4	4X4	5X4	6X4	1X5	2X5	3X5	4X5	5X5	6X5	GND	GND	GND	GND	GND	GND
												P8	P8	P8	P8	P8	P8

TERMINAL BLOCK MARKER STRIPS

TB1	TB2	TB3	TB5	TB6	TB7	TB8	TB9	TB10	TB11	TB4
1	2	3	5	6	7	8	9	10	11	3
7R	8R	9R	17	18	19	20	21	22	23	31
1A	2A	3A	5A	6A	7A	8A	9A	10A	11A	32
125	126	127	128	129	130	131	132	133	134	33
135	136	137	138	139	140	141	142	143	144	34
145	146	147	148	149	150	151	152	153	154	35
155	156	157	158	159	160	161	162	163	164	36
										P5


BCT TERMINAL MARKER STRIP NOTES:
 1) STRIP MATERIAL: PLASTIC - YELLOW WITH BLACK LETTERS
 2) STRIP DIMENSIONS AS SHOWN ON FABRICATION DRAWING "L_417_376_P1" (SEE PPS FOR EACH STRIP)

TERMINAL MARKER STRIP NOTES:
 1) STRIP MATERIAL: PLASTIC - BLACK WITH WHITE LETTERS
 2) STRIP DIMENSIONS AS SHOWN ON FABRICATION DRAWING "L_417_376_P1" (SEE PPS FOR EACH STRIP)

DEVICE TAGS

AT2	EA1	DT1	ES	H1	HT1	L1
	63GX1	49	52Y	2X 95 W		40 W
LS1	M1	MA1	MA2	MA3	MA4	MB1
	88	52-1	52-2	52-3	52-4	88LS
MC	MD	ME	PL1	S1	S2	S3
52CC	52TC1	52TC2	GFI	15A	15A	15A
S4	S6	TH1				
20A	15A	23-1				

DEVICE TAG NOTES:
 1) TAG MATERIAL: PLASTIC - YELLOW WITH BLACK LETTERS
 2) TAG DIMENSIONS AS PER FABRICATION DRAWING "L_417_376_P1"



CUSTOMER ORDER No.
 SUBSTATION SERIAL No.
 CUSTOMER EQ. No.

DRAWN BY
 CHECKED
 DATE

DRAWN
 CHECKED
 DATE

ECN NO.

REV. DESCRIPTION

DEVICE TAGS

DRAWING No. DT1-145FK F1
 SHT 12 OF 13

MATERIAL ID: CCDT1-145FK-F1-001
 ORDER No.

SAMPLE DRAWING

Grid Solutions
 One Power Lane
 Charlotte, PA 15022



DT1-145 DT1-170

Dead Tank Circuit Breakers from 123 kV to 170 kV

The DT1-145 and the DT1-170 are dead tank circuit breakers suitable for application at 170 kV and below. They are specifically designed and tested for general or definite purpose applications as well as for severe environmental conditions including low temperature, highly active seismic areas and regions with high pollution levels or corrosive atmospheres.

Reliable Performance

The DT1-145 and the DT1-170 are suitable for applications up to nameplate ratings, including definite purpose ratings. Extensive mechanical design testing to 10,000 operations and Class M2 certification ensure trouble-free operation for the lifetime of the circuit breaker.

Gas Tightness Guarantee & Superior Manufacturing

GE leads the industry in SF₆ gas tightness testing technology including seals, castings and plumbing systems. Each breaker is factory tested using GE's proprietary gas tightness testing system which provides measurable, quantifiable test results on the breaker in its fully assembled, as-shipped condition.


GE designs, manufactures, tests and delivers its circuit breakers in accordance with the latest IEEE/ANSI and IEC Standards, maintaining a quality assurance system according to ISO 9001 and ISO 14001 certifications. The center of excellence for dead tank circuit breakers is located in Charleroi, PA (USA).

Enhanced Installation and Maintenance

The DT1-145/170 are factory tested and adjusted and do not require any "special tools" for the installation. Designed with the smallest symmetrical footprint to allow for minimized foundation costs, they are recognized worldwide as easy-to-install and operate circuit breakers. Thanks to the low energy mechanism and lifetime lubricants, the DT series is virtually maintenance free. For installations where truck shipment is impossible, all DT series circuit breakers can be readied for standard container shipment with only their bushings disassembled.

IPO Option

The DT1-145 and the DT1-170 are also available in Independent Pole Operation (IPO) configuration with separated spring/spring mechanism for each phase. Paired with a synchronous controller this can be used for point-on-wave switching of shunt capacitor or shunt reactor banks.



Main Characteristics

- Advanced self-blast interrupters
- Leak resistant cast aluminum enclosures
- Durable low energy spring-spring-operated mechanism
- More than 100,000 circuit breakers with self-blast interrupters and FK spring-operated mechanism in service since 1989

Key Benefits


- SF₆ gas tightness guarantee
- High performance ratings
- Reliability under the most severe conditions
- Design customization
- Virtually maintenance free
- Easy to install



Technical Data

	Value	Units
SF ₆ pressure	93/0.64	psig/Mpa
Motor	1,600	watts
Close coil/Trip coil	440/440	watts
Ambient temperature range*	-30 to +40	degree C
High seismic capability in accordance with IEEE 693-2005		
Weight (without current transformers)	4,180/1,900	lb/kg

* Optional values available on request



Dimensions

Rated Max. Voltage	A (in/mm)	B (in/mm)	C (in/mm)	D (in/mm)	E (in/mm)	F (in/mm)	G (in/mm)	H (in/mm)
145 kV	90/2,284	70/1,779	136/3,459	169/4,289	54/1,372	90/2,284	69/1,747	102/2,600
170 kV	90/2,366	73/1,849	146/3,719	179/4,549	54/1,372	153/3,898	74/1,881	102/2,591

Ratings

IEEE	IEC	Value	Units
Rated maximum voltage	Rated voltage	123/145/170	kV
Rated power frequency	Rated frequency	50/60	Hz
Rated dielectric withstand capability	Rated insulation level		
dry withstand	at power frequency, dry	260/310/365	kV
wet withstand	at power frequency, wet	230/275/315	kV
Rated lightning impulse withstand voltage	at lightning impulse	550/650/750	kV
Rated chopped wave impulse voltage 2us		710/838/968	kV
Rated continuous current	Rated normal current	1,200/2,000/3,000	A
Rated short-circuit current	Rated short-circuit breaking current	40	kA
Rated closing, latching, and short time carrying		104	kA
Rated capacitance switching*			
	Rated single capacitor bank breaking current	400	A
Rated interrupting time		3	cycles
	Rated break time	50	ms
Rated standard operating duty	Rated operating sequence	O-0.3s-CO-15s-CO	

* Ratings available upon request. ** Please contact GE for special purpose, high TRV, high X/R or other ratings requirements.

For more information please contact
GE Energy Connections
Grid Solutions

Worldwide Contact Center

Web: www.GEGridSolutions.com/contact
Phone: +44 (0) 1785 250 070

GEGridSolutions.com

GE and the GE monogram are trademarks of General Electric Company.

GE reserves the right to make changes to specifications of products described at any time without notice and without obligation to notify any person of such changes.

© Copyright 2017, General Electric Company. All Rights Reserved.

Grid-AIS-L3-DT1-123_170-0277-2017_01-EN.



imagination at work


SF₆ Gas Tightness Testing System

GE's Grid Solutions has perfected its industry leading production testing system for every 38kV through 550kV kV dead tank circuit breaker produced in our Charleroi, Pennsylvania factory. The system not only confirms SF₆ gas tightness and also quantifies the exact emission rate, with accuracy of 0.2 grams/year,

Grid Solutions' proprietary technology utilizes photo-acoustic infrared spectroscopy which is the highest possible sensitivity method for leak detection.


Our technology provides:

- Sensitivity **5,000 times greater** than "bubble" test or infrared camera.
- **Sensitivity 10 ten times** greater than helium mass spectrometer method with accuracy of 0.2 grams per year compared to 2 grams per year.
- Every breaker produced is **tested fully assembled with bushings installed** (as-delivered condition for domestic delivery) while helium mass spectrometer only tests smaller components such as castings.
- **High accuracy measurement** of less than 0.5% per year emission rate in a routine production test environment.



550 kV Dead Tank
Volumetric Tightness Testing

Photo-Acoustic Infrared Spectroscopy



SF₆ Leak Detection Methods

Comparison of detection methods
CIGRE Technical Brochure No. 430 "SF₆ Tightness Guide"

Method	Sensitivity (kg/year)	Ratio vs. bubble test
Vacuum increase	1.0	10
Infrared camera	1	1
Bubble test	1	1
Density monitor	0.6	1.7
Infrared absorption spectroscopy	0.06	16.7
Negative ion detector	0.02	50.0
Electron capture detector	0.002	500.0
Helium mass spectrometer	0.002	500.0
Photo-acoustic infrared spectroscopy	0.0002	5000.0

• **Greatest Sensitivity and Accuracy**

▶ Method used by Grid Solutions for Type Tests and Production


Photo Acoustic Infrared Spectroscopy



SF₆ Emissions Reductions



Every dead tank circuit breaker produced in the Charleroi, Pennsylvania factory from 38kV to 550kV is tested with Grid Solutions' proprietary technology in use since 2010 at this site.

The graph shown to the right illustrates the dramatic improvement realized after implementation of 72.5kV production testing.



Multiple systems for High Volume Production

Multiple systems allow for high efficiency testing of every fully assembled dead tank circuit breaker from 38kV to 550kV. The systems are scaled to allow for highly accurate measurements as an automated routine production test.



Grid Solutions' commitment to reducing SF₆ emissions extends from our robust designs with high grade gaskets to testing and certification. Our continuing efforts provide for quantifiable reduction in SF₆ emissions for our customers resulting in industry leading reliability and lower cost of maintenance.

GEGridSolutions.com

GE and the GE monogram are trademarks of General Electric Company.

GE reserves the right to make changes to specifications of products described at any time without notice and without obligation to notify any person of such changes.

Copyright 2016, General Electric Company. All Rights Reserved.



imagination at work



Line Card

High Voltage Circuit Breakers

Grid Solutions offers a comprehensive portfolio of high voltage circuit breakers designed and tested to meet the rigorous demands of the North American power system

Product		Ratings	Features
DT1-38FK F1		<ul style="list-style-type: none"> • Up to 38kV • 1200A to 3000A • 40kA, 3 cycles 	<ul style="list-style-type: none"> • FK3-1 SPRING/SPRING mechanism • Gang Operated
DT1-72.5FK F1		<ul style="list-style-type: none"> • 72.5kV • 1200A to 3000A • 40kA, 3 cycles 	<ul style="list-style-type: none"> • FK3-1 SPRING/SPRING mechanism • Gang Operated
DT1-72.5FK F3		<ul style="list-style-type: none"> • 72.5kV • 1200A to 3000A • 40kA, 3 cycles 	<ul style="list-style-type: none"> • FK3-1 SPRING/SPRING mechanisms • Independent Pole Operation (IPO) • Optional Synchronous Control for Point-on-Wave Switching
DT1-145FK F1 DT1-170FK F1		<ul style="list-style-type: none"> • 123kV, 145kV, 170kV • 1200A to 3000A • 40kA, 3 cycles 	<ul style="list-style-type: none"> • FK3-1 SPRING/SPRING mechanism • Gang Operated
DT1-145FK F3 DT1-170FK F3		<ul style="list-style-type: none"> • 123kV, 145kV, 170kV • 1200A to 3000A • 40kA, 3 cycles 	<ul style="list-style-type: none"> • FK3-1 SPRING/SPRING mechanisms • Independent Pole Operation (IPO) • Optional Synchronous Control for Point-on-Wave Switching
DT1-72.5 63 DT1-145 63		<ul style="list-style-type: none"> • 72.5kV, 123kV, 145kV • 1,200A to 4,000A • 63kA, 3 cycles 	<ul style="list-style-type: none"> • FK3-4 SPRING/SPRING mechanism • Gang Operated • NO CAPACITORS
DT1-245P F1		<ul style="list-style-type: none"> • 245kV • 1,200A to 4,000A • 40kA, 3 cycles 	<ul style="list-style-type: none"> • FK3-4 SPRING/SPRING mechanism • Gang Operated • Optional 2 cycle performance
DT1-245P F3		<ul style="list-style-type: none"> • 245kV • 1,200A to 4,000A • 40kA, 3 cycles 	<ul style="list-style-type: none"> • FK3-1 SPRING/SPRING mechanisms • Independent Pole Operation (IPO) • Optional Synchronous Control for Point-on-Wave Switching
DT1-245P 63		<ul style="list-style-type: none"> • 245kV • 1,200A to 5,000A • 63kA, 2 cycles 	<ul style="list-style-type: none"> • SPRING/SPRING mechanisms • Gang Operated • NO CAPACITORS
Surge Arresters for Reactor Switching		<ul style="list-style-type: none"> • 72.5kV to 550kV • Dead Tank, Live Tank, Circuit Switcher • Arresters sized based on user specifications. 	<ul style="list-style-type: none"> • Arresters across HV Terminals extend circuit breaker life • External mounting for increased reliability and ease of maintenance



Line Card
High Voltage Circuit Breakers

Product		Ratings	Features
DT1-362 F3 DT1-362R F3		<ul style="list-style-type: none"> • 362kV • 1,200A to 5,000A • 63kA, 2 cycles 	<ul style="list-style-type: none"> • FK3-6 SPRING/SPRING mechanism • Independent Pole Operation (IPO) • Optional Synchronous Control for Point-on-Wave Switching • Optional Pre-Insertion Resistors (PIR)
DT2-550 H3 DT2-550 F3 DT2-550R H3 DT2-550R F3		<ul style="list-style-type: none"> • 550kV • 1,200A to 5,000A • 63kA, 2 cycles 	<ul style="list-style-type: none"> • Hydraulic Mechanisms • Independent Pole Operation (IPO) • Optional Point-on-Wave Switching • Optional Pre-Insertion Resistors (PIR) • Optional SPRING/SPRING Mechanism
GL3 Series Live Tank		<ul style="list-style-type: none"> • 72.5kV to 800kV • 1,200A to 4,000A • Up to 63kA, 3 cycles 	<ul style="list-style-type: none"> • FK3-x SPRING/SPRING mechanism • Independent Pole Operation (IPO) • Or Gang Operated (voltage dependent)
Live Tank GL309 GL312 GL313 GL314		<ul style="list-style-type: none"> • 72.5kV to 245kV • 1,200A to 3,000A • Up to 40kA, 3 cycles 	<ul style="list-style-type: none"> • Circuit Switcher applications • FK SPRING/SPRING operated mechanism • Circuit Breaker performance in a Circuit Switcher footprint
GL314 BPS Bypass Switch		<ul style="list-style-type: none"> • Up to 800kV system • Up to 170kV across gap • Making Current 120kAp • Insertion Current 5,000A • Insertion Voltage 300kVp 	<ul style="list-style-type: none"> • Series Capacitor Bypass Protection • FK3-2 SPRING/SPRING mechanism • Independent Pole Operation
HYpact		<ul style="list-style-type: none"> • 72,5 kV to 170kV • 2,500A • 40kA, 3 cycles • Hybrid compact switchgear assembly 	<ul style="list-style-type: none"> • FK3-1 SPRING/SPRING mechanism • Gang Operated • Endless configurations - breakers, disconnect switches, CTs, VTs, cable connections.
g ³ ("gee-cubed")		<ul style="list-style-type: none"> • Ratings are product and customer specific. 	<ul style="list-style-type: none"> • SF₆ Free • Global Warming Potential 98% lower than SF₆ gas 
CBWatch3		<ul style="list-style-type: none"> • Circuit Breaker Monitoring • IEC 61850 8.1 (DNP3 option) 	<ul style="list-style-type: none"> • Permanent real-time monitoring of CB operational parameters • SF6 emissions trending
Synchronous Control (Point on Wave Switching)		<ul style="list-style-type: none"> • Cabinet mounted or Rack Mounted 	<ul style="list-style-type: none"> • Point-on-wave (POW) trip/close • Capacitors, reactors, transformers • Residual Flux compensation available

* Special ratings and applications available on request. Contact your GE representative for more information.



Item	Material	Description
10	Capacitor Voltage Transformer	TEMP145 Rated Voltage 138 kV , Capacitance 10,400 pF , Type of Insulator Porcelain , Creepage 148 IN , No. of Secondaries 2 , Carrier accessory Yes ,

Note: We offer our CVT model TEMP145 to meet the minimum required capacitance of 6,000pF

Testing: Price includes Routine Testing according to the quoted standards only. Type test reports of similar units can be provided in lieu of performing type tests upon request at no charge.
Actual type tests, if required, would be charged extra. If type testing is required, delivery dates may be affected.

Warranty: 60 months in service ,maximum 66 months from delivery
Warranty only applies to products manufactured and supplied by Trench Group.

Our standard manuals as well as the following drawings are included in our supply:

- outline drawing with details of primary terminal, grounding terminal and mounting holes
- wiring diagram
- rating plates
- secondary terminal box

Painting of transformers:

All iron parts are hot-dip galvanized or of stainless steel. Other metal parts are of corrosion resistant cast aluminum and additional painting is not necessary.

All terminal box / enclosures meet the degree of protection IP54.

CVT supplied with oil level indicator on electromagnetic unit only.

If applicable, carrier accessories include:

- in low voltage box: drain coil with protective spark gap and carrier ground switch;
- in base box: choke coil with protective spark gap and voltage tap ground switch (if required).

If applicable, Line Trap mounting holes 4 x 5/8–11 inch tapped on 5 inch [127 mm] BCD. (Alternatively, holes tapped on 11.65 inch [296 mm] BCD available upon request.)

For Line Trap mounting feasibility, please consult the factory.

CVT designed with:

- Transient response < 10 % residual voltage after 1 cycle;
 - Ferroresonance suppression < 10 cycles;
 - Capacitor section supplied with mixed dielectric (polypropylene film / Kraft paper) impregnated with synthetic oil.
- Dissipation factor < 0.4 %.



TEMP145

Trench proposal #.....22012921 Item #.....000010

Product Type	TEMP145
Quantity	4.000
Standard	ANSI C93.1

Altitude above sea level ft	3,300 FT
Temperature range Min.	-40 °C
Temperature range Max.	45 °C
Wind speed maximum	100MPH
Seismic specification	ANSI

Rated System Voltage	138 kV
Max System Voltage	145.0 kV
Frequency	60 Hz
1 Minute Dry withstand	320 kV
10 Second Wet Withstand	275 kV
Switching Insulation Level	0 kV
Basic Impulse Level	650 kV
Over Voltage Factor	1.4/60s

Nominal Capacitance	10,400 pF
---------------------	-----------

Performance Reference Voltage	80,500 V
Max Thermal Burden	1000VA

Number of secondary windings	2
------------------------------	---

Secondary Volt full winding w1	115 V
--------------------------------	-------

THE PROVEN POWER.
www.trench-group.com



Secondary Voltage tap W1	67.08 V
Accuracy W1	0.3
Burden W1	WXYZ,ZZ
Ratio W1	700/1200:1

Secondary Volt full winding w2	115 V
Secondary Voltage tap W2	67.08 V
Accuracy W2	0.3
Burden W2	WXYZ,ZZ
Ratio W2	700/1200:1

Simultaneous Accuracy	0.3
Simultaneous Burden	WXYZ,ZZ

Base Box Style	Universal
Carrier accessory	Yes
Drain coil	10 mH

Total sections	1
Color of Insulator	Grey
Type of Insulator	Porcelain
Creepage distance in	148 IN
Flashover distance in	47 IN
Max. term. pull-80 mph wind	1,079 LB

Dimensions as per drawing	SMP14Y0U
Net Weight	740 LB
Gross Weight	773 LB
Crate Length	36 IN
Crate Width	24 IN
Crate Height	88 IN

Primary Terminal	AI NEMA 4 holes
Primary Connector	No
Ground Terminal	AI NEMA 2 holes Tin
Ground Connector	No
Secondary Terminal Type	Screw type integrated

Trench Limited
1865 Clements Road
Pickering, Ontario
Canada L1W 3R8
Quote # 22012921
Unrestricted


Tel: 416 751 8570
24/7 Toll free: 1844 873 6241
Fax: 416 751 6952
Email: edna.romero@trench-group.com




Secondary Protection No

Additional Accessories

Heater	Yes
Additional Spark Gap	No
Oil Drain Valve	No
Harmonic Monitoring Device	No
Damping Pads	No
Bellow level indicator	No
Shock Indicator	No
Suspension Bracket	No
Low Voltage Box K.O.	No
LV Box Interlocking	No
Gland Plate K.O.	No




TOLERANCES UNLESS OTHERWISE SPECIFIED 0-12" [305] ±1/32" [0.8] 12" [305]-24" [610] ±1/16" [1.6] 24" [610]-36" [914] ±3/32" [2.4] 36" [914]-48" [1219] ±1/8" [3.2] 48" [1219] AND UP ±3/16" [4.8] WEIGHT ±10% ANGULAR ±2°	REVISION No. DESCRIPTION		TRENCH LIMITED COPYRIGHT, ALL RIGHTS RESERVED				 TRENCH
	CAPACITOR VOLTAGE TRANSFORMER TYPE TEMP 145		DESG.	DRN.	APPD.	DATE	
						DWG.	SMP14YOU

OHIO BRASS QUADRI-SIL SUSPENSION INSULATOR

CAT NO.:	S030047S2010	
REV:	00	March 4, 2018



HUBBELL POWER SYSTEMS, INC.
 CUSTOMER SERVICE: (573) 682-5521
www.hubbellpowersystems.com



MECHANICAL VALUES

MAX DESIGN TENSILE LOAD (RTL)	LBS	30000	KN	133
SPECIFIED TENSILE LOAD (STL)		15000		66.5

ELECTRICAL VALUES

60 HZ DRY FLASHOVER (DRY WITHSTAND)	500	KV	-
60 HZ WET FLASHOVER (WET WITHSTAND)	475		(355)
CRITICAL IMPULSE FLASHOVER + (WITHSTAND)	800		(720)
CRITICAL IMPULSE FLASHOVER - (WITHSTAND)	795		(715)
RV AT 115% SYSTEM VOLTAGE	≤100 μV		

DIMENSIONAL VALUES

SECTION LENGTH (A)	IN.	59.2	MM	1503
MAJOR SHED DIAMETER (B)		2.9		73
MINOR SHED DIAMETER (C)		0		0
DRY ARC DISTANCE		47.4		1203
SHEATH THICKNESS		>0.118		>3
LEAKAGE DISTANCE		121		3073

END FITTINGS AND MATERIALS

TOWER END: ANSI 52-5 BALL / GALV STEEL
 LINE END: Y-CLEVIS / GALV STEEL

NOTES:


- SILICONE RUBBER SHEATH AND SHEDS. WASHABLE PER IEEE P957
- ELECTRICAL VALUES PER ANSI C29.17 (IEC 61109 & 62217)

OTHER DETAILS

CORONA RING (TOWER)	NONE
CORONA RING (LINE)	NONE
TORQUE REQUIREMENTS	N/A
MOUNTING ANGLE	-
NUMBER OF SHEDS	44
WEIGHT	8.7 lbs. / 3.9 kg.

TECHNICAL PARTICULARS

4 Holes 5/8"-11UNC(0.015"Oversize)
X0.866" deep on 5" PCD



4 Holes 5/8"-11UNC(0.015"Oversize)
X0.866" deep on 5" PCD

MECHANICAL VALUES

Bending strength (Upright & under hung)	lb	2200	kN	9.78
Compression strength	lb	75000	kN	333.6
Tensile strength	lb	25000	kN	111.2
Torsional strength	in lb	90000	kNm	10.17

ELECTRICAL VALUES


Dry power frequency withstand voltage	kV	335
Wet power frequency withstand voltage	kV	275
Dry power frequency flashover voltage	kV	365
Wet power frequency flashover voltage	kV	305
Lightning impulse withstand voltage	kVp	650
Impulse flash over voltage	kVp	710
Min. creepage distance	inch. 116	mm 2946
Net Weight (approx.)	161 lbs	kgs 73
Shed profile as per IEC : 60815		

RADIO INFLUENCE VOLTAGE DATA

Test voltage to ground	kV	88
Max. RIV at 1000 kHz	µV	200

NOTE: -

Test & tolerance as per IS :2544 , 5350 & IEC:60168,273
& ANSI : C 29.9




Marking at top shed

2	Caps	MCI / SGI	Hot dip galv .
1	Insulator body	Porcelain	Grey Glazed
S.No.	DESCRIPTION	MATERIAL	REMARKS


Title STATION POST INSULATOR (BIL - 650 kV)	Scale N.T.S.	Matl. See table
Ref. 47822-7001 [TR-289]	Drawn Kirti Nambiar	Checked S.K.dixit
	Approved KR JC	Date 06-02-1998
	All dimension are in mm /inch.	

NEWELL PSN LLC

Rev.




LINE TERMINAL DETAIL



HDG 4-HOLE TERMINAL PAD, PART No. 274914-4002
 TWO HDG TERMINALS, PART No. 271414-3001
 SUITABLE FOR COPPER OR ALUMINUM CONDUCTOR SIZE
 Ø 7 (.25) - Ø 21 (.81)
 25 - 240 sq mm
 AWG#4 - 500 MCM

GROUND TERMINAL DETAIL



HDG TERMINAL BRACKET, PART No. 89606-4001
 ONE HDG TERMINAL, PART No. 271414-3001
 SUITABLE FOR COPPER OR ALUMINUM CONDUCTOR SIZE
 Ø 7 (.25) - Ø 21 (.81)
 25 - 240 sq mm
 AWG#4 - 500 MCM

Ø = DIAMETER
 HDG = HOT DIP GALVANIZED

CHARACTERISTICS	
RATED VOLTAGE (Ur)	108 kVrms
MCOV (Uc)	88 kVrms
MASS	26.7 kg (58.9 lb)
COG ABOVE BASE	589 (23.2)
CREEPAGE DISTANCE	3124 (123)
STRIKE DISTANCE	1100 (43.3)
LIGHTNING IMP W/S	631 kVpk
SWITCHING IMP WET W/S	529 kVpk
POWER FREQ WET W/S	275 kVrms
TOV 1s NO PRIOR DUTY	125 kVrms
TOV 10s NO PRIOR DUTY	120 kVrms
TOV 1s W/PRIOR DUTY	119 kVrms
TOV 10s W/PRIOR DUTY	113 kVrms

CANTILEVER FORCE	
MAXIMUM CONTINUOUS	897 N (202 lbf)
ULTIMATE (max pk)	1794 N (403 lbf)

RECOMMENDED CLEARANCE (METAL - METAL)	
PHASE TO GROUND	503.1 (19.8)
PHASE TO PHASE	582.4 (22.9)

- NOTES:
 1. DIMENSIONS IN millimeters(inches) SUBJECT TO ±3% TOLERANCE
 2. CLEARANCE AND INSULATION W/S VOLTAGE APPLY AT SEA LEVEL
 3. ARRESTER SUITABLE FOR OPERATION AT ALTITUDES UP TO 4380 m (14370 ft)
 4. PACKAGED IN A CORRUGATED BOX.

.5µ SEC 10KA IR KV	SWITCHING SURGE IR KV		MAXIMUM 8/20 DISCHARGE VOLTAGE - KV AT					
	500 A	1 KA	1.5 KA	3.0 KA	5 KA	10 KA	20 KA	40 KA
289	207	216	221	232	244	261	283	322

IEEE C62.11
 STATION-CLASS
 SURGE ARRESTER
 Program Revision
 2015.07.30.08.09.10
 REV DATE **05/03/11**

CONFIDENTIAL: THIS DRAWING AND ITS CONTENTS ARE CONFIDENTIAL AND THE EXCLUSIVE PROPERTY OF HUBBELL POWER SYSTEMS. NO PUBLICATION, DISTRIBUTION OR COPIES MAY BE MADE WITHOUT THE WRITTEN CONSENT OF HUBBELL POWER SYSTEMS. HUBBELL POWER SYSTEMS UNPUBLISHED ALL RIGHTS RESERVED UNDER THE COPYRIGHT LAWS.

TITLE **EVP ARRESTER
88 KV MCOV**

SIZE S	DWG NO. 181962397	CAT / PART / ASSY NO. EVP0088003001	REV 1
DO NOT SCALE THIS DRAWING	DRN BY NON	DATE 05/03/11	SHEET 1 OF 1